

Letter of Attestation

Document: 80191576

Project: 80191576

Master Contract: 178267

Date Issued: February 24, 2025

Issued to: Hawke International A Division of Hubbell Limited Oxford St W Ashton-Under-Lyne, Manchester, OL7 0NA United Kingdom Attention: Sim Mashanga

CSA Group hereby confirms that it has completed an evaluation of:

Cable Gland Model	Type Rating
501 / 414	4
501 / 453UNIV	4X
501 / 453 RAC	
501 / 423	
501 / 421	

CSA Group hereby attests that the products identified above and described in APP A test report 80191576 dated 2025-02-05 and drawings in APP B Drawings 80191576 complies with the following standards/tests required for Enclosure Type 4, to the extent applicable:

CSA C22.2 No. 94.2-20/UL 50E-20 Clause 8.6 – Hosedown Test CSA C22.2 No. 94.2-20/UL 50E-20 Clause 8.13.2 – Tensile strength and elongation test

And with the following standards/tests required for Enclosure Type 4X, to the extent applicable C22.2 No. 94.2-20/UL 50E-20 Clause. 8.9.1 – 200-hour salt-spray test



Document:80191576Project:80191576

Master Contract: 178267 Date: Febrary 5, 2025

The following tests has been deemed to be not applicable based on a construction review:

CSA C22.2 No. 94.2-20 /UL 50E-20 Clause 8.4.1.1 – Outdoor dust, dust blast method (no ventilated devices)

CSA C22.2 No. 94.2-20 /UL 50E-20 Clause 8.5 – External Icing (no external cavities) CSA C22.2 No. 94.2-20 /UL 50E-20 Clause 8.8 – Outdoor corrosion protection (based on material)

CSA C22.2 No. 94.2-20 /UL 50E-20 Clause 8.13.3 – Compression test (Gasket between parts, not to be

opened)

CSA C22.2 No. 94.2-20/UL 50E-20 Clause 8.15 – Misalignment (no conduits)

Issued by: Thomas Büchting

CSA Group

THIS LETTER OF ATTESTATION DOES NOT AUTHORIZE THE USE OF THE CSA MARK ON THE SUBJECT PRODUCTS.

QUOTATIONS FROM THE TEST REPORT OR THE USE OF THE NAME CSA GROUP OR ITS REGISTERED TRADEMARK, IN ANY WAY, IS NOT PERMITTED WITHOUT PRIOR WRITTEN CONSENT OF CSA GROUP TESTING & CERTIFICATION INC