



中国国家强制性产品认证证书

证书编号: 2024312313000614

认证委托人名称及地址

Hawke International (A Division of Hubbell Limited, A member of the Hubbell group of Companies)

Oxford Street West, Ashton-Under-Lyne, Lancashire, OL7 0NA, UK

生产者名称及地址

Hawke International (A Division of Hubbell Limited, A member of the Hubbell group of Companies)

Oxford Street West, Ashton-Under-Lyne, Lancashire, OL7 0NA, UK

生产企业名称及地址

Hawke International (A Division of Hubbell Limited, A member of the Hubbell group of Companies)

Oxford Street West, Ashton-Under-Lyne, Lancashire, OL7 0NA, UK

产品名称和系列、型号、规格

电缆引入装置

APEX A2F

Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da

产品标准和技术要求

GB/T 3836.1-2021, GB/T 3836.2-2021, GB/T 3836.3-2021, GB/T 3836.31-2021

上述产品符合《强制性产品认证实施规则 防爆电气》

(CNCA-C23-01: 2019) 的要求, 特发此证。

发证日期: 2024年04月26日 有效期至: 2029年04月25日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



法定代表人:

南阳防爆电气研究所有限公司



中国国家强制性产品认证证书

证书编号：2024312313000614

证书附页：第 1 页 共 2 页

产品相关信息：

1、本证书覆盖产品如下：

— APEX A2F

APEX A2F 规格：

规格代码	螺纹类型		螺纹长度 (最小)	
	M	NPT	M	NPT
0s	M16×1.5	—	15.0	—
	M20×1.5			
0	M16×1.5	1/2"	15.0	20.5
	M20×1.5			
A	M20×1.5	1/2"	15.0	20.5
B	M25×1.5	3/4"	15.0	20.8
C	M32×1.5	1"	15.0	25.65
C2	M40×1.5	1 1/4"	15.0	26.27
D	M50×1.5	1 1/2"	15.0	26.69
E	M63×1.5	2"	15.0	27.53
F	M75×1.5	2 1/2"	15.0	40.56
		3"		42.15

APEX A2F 型电缆引入装置用于圆形编织覆盖层和非铠装电缆, 包括以下组件：

- a) 用于防护的垫圈 (可选)
- b) 引入部分, 尺寸范围 M16...M75, NPT1/2" ...NPT3"
- c) 可压缩密封圈
- d) 滑环
- e) 压紧螺母

本页为证书附页, 应与证书主页同时使用。



南阳防爆电气研究所有限公司





中国国家强制性产品认证证书

证书编号：2024312313000614

证书附页：第2页 共2页

外壳防护等级：IP66/IP67

防爆标志：Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da

— 生产者应按照认证机构批准的技术文件组织生产。

2、安全使用条件：

— 工作温度：-60℃~+130℃。

— 当用于增安型（气体环境）或防粉尘点燃外壳型（粉尘环境）外壳时，引入口螺纹应适当密封以满足相应外壳防护等级。

— 当用于导管、非铠装或带编织覆盖层电缆时，仅适用于固定安装，其电缆必须被有效地夹紧，以防止拉力和扭矩。

— 其他见产品使用说明书。

3、证书关联报告：

— 产品型式试验报告：CQST2401C016

4、证书变更信息：无。

本页为证书附页，应与证书主页同时使用。



南阳防爆电气研究所有限公司

