

## Conditions of Acceptability

When installed in the end-use equipment, the following are among the considerations to be made:

1. The outputs of the units comply with Class 2 criteria of UL 1310.
2. The output of Model LED12W-48 series exceeds the Class 2 criteria of CSA C22.2 No. 223 and only complies with Class 2 criteria of UL 1310.
3. These products have been evaluated for use in dry or damp location.
4. The temperature test needs to be conducted in the end product and the measured maximum temperature on transformer is to be max. 105°C and the maximum housing surface temperature is 105°C.
5. These LED drivers are of the constant current type that requires the proper number of LED modules and controllers that does not exceed the max. output voltage.
6. These LED Drivers have housings that do not qualify as being enclosure rated so they must be installed within an end product enclosure.