Vol. 1 Sec. 35 Page 4 Issued: 2013-11-02 and Report

TECHNICAL CONSIDERATIONS (NOT FOR UL FIELD REPRESENTATIVE USE):

The construction and performance of the representative models of the series were in accordance with the safety requirements specified in the following standards for safety:

- USR Indicates investigation to the standard for light emitting diode (LED) light sources for use in lighting products, UL8750, first edition
- CNR Indicates investigation to Canadian standard for General Use Power Supplies, C22.2 No. 107.1-01, reaffirmed 2006

Use - For use only in (or with) complete equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

Conditions of Acceptability - When installed in the end-use equipment, the following are among the considerations to be made:
Conditions of Acceptability:

- The drivers shall be installed in compliance with the mounting, spacing, casualty, and segregation requirements of the ultimate application.
- 2. The drivers are suitable for use in "DRY" and "DAMP" locations
- 3. The primary circuit leads are 18 AWG, rated VW-1, 600 V, 105□C, and the output leads are 18 AWG, rated VW-1, 300 V minimum. The dimming circuit leads are 22 AWG, rated VW-1, 300 V minimum. The suitability of the input and output leads shall be determined in each end use application.
- 4. The case temperature at the location identified "Tc" as shown in Illustration- 1 should not exceed 90 □C when the drivers are installed in the end-use application.
- 5. The housing of these drivers was not evaluated to determine the suitability as an ultimate enclosure. Therefore, the drivers must be installed inside the enclosure of the end-use application.
- 6. The input and output leads were not subjected to the strain relief test. However, the drivers are completely filled with potting compound.
- 7. If the Leakage current measurements are required in the end-use application, the test shall be performed on the combination at the equipment connection in the end-use product.
- 8. As required in paragraph 7.4.2.2 of UL8750 standard for Field-wiring leads, the primary, Green or Green/Yellow Stripe Grounding lead is 18-AWG and is directly connected to the case of the driver with a closed loop crimp-on type connector screwed directly to a case mounted lug.
- 9. The dimming circuit is isolated from the primary circuit and is considered part of the output Secondary circuit.

Vol. 1 Sec. 35 ILL-1 Issued: 2013-11-02 and Report

## Mechanical Dimensions: Inches [mm]

Material: Black Aluminum Housing Fully Encapsulated Weight: 690 grams (24.4 oz) Typical

