

Conditions of Acceptability - When installed in the end product, consideration shall be given to the following items:

1. The transformer employs a Class 130(B) Insulation System.
2. The transformer should be mounted in the intended manner in an enclosure having adequate strength and thickness with acceptable spacing being provided.
3. The suitability of mounting means shall be determined in the end-use application.
4. The suitability of primary and secondary leads/connections shall be determined in the end-use application.
5. The Temperature Test was performed at a 25°C ambient. The necessity of repeated Temperature Test shall be determined in the end-use application.
6. This is an autotransformer construction. No isolation is provided from the primary to secondary winding.
7. The transformer shall be used within its Recognized rating as specified above.