



# Certificate of Compliance

**Certificate:** 80074965 (LR 11716-102)

**Master Contract:** 151933

**Project:** 80074965

**Date Issued:** 2021-05-11

**Issued To:** Killark, Div of Hubbell Inc. (Delaware)  
2112 Fenton Logistics Park Blvd  
Fenton, Missouri, 63026  
United States

**Attention:** Tom Michalski

*The products listed below are eligible to bear the CSA Mark shown*

**Issued by:** *Zafar Iqbal*  
Zafar Iqbal



## **PRODUCTS**

**CLASS 4418 03 - CONDUIT FITTINGS - Fittings for Metal Conduit - For Hazardous Locations**

**Class 1, Groups A, B, C, D; Class 11, Groups E, F, G; Class III:**

Aluminum NPT Adaptors, Cat Nos ADUP- 01, ADUP-12 and ADUP-23, conduit size 1/2, 3/4 and 1-inch sizes respectively.

## **APPLICABLE REQUIREMENTS**

- CSA C22.2 NO. 0.5:2016 - Threaded conduit entries - Third Edition
- CSA C22.2 NO. 18.3:2012 - Conduit, tubing, and cable fittings – Second Edition;
- CSA C22.2 NO. 25: 1966 - Enclosures for use in Class II, Division 1, Groups E, F, and G hazardous locations - Fourth Edition
- CSA C22.2 NO. 30-M1986 (R 2016) - Explosion-proof enclosures for use in class I hazardous locations - Third Edition



**Certificate:** 80074965  
**Project:** 80074965

**Master Contract:** 151933  
**Date Issued:** 2021-05-11

---

## **MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark, without any adjacent indicators, indicating that products have been manufactured to the requirements of Canadian Standards.

Following data are either metal stamped or molded on each device:

Submitter's name and/or trademark, catalogue designation, hazardous location designation\*, and the CSA Monogram.

Note: \*Due to limited space, designation of hazardous location "GROUPS" may be omitted in the marking.



## *Supplement to Certificate of Compliance*

**Certificate:** 80074965

**Master Contract:** 151933

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80074965	2021-05-11	Update to CSA report # LR 11716-102 to add a new 1inch adapter ADUP-23, and update standards.
LR 11716-102	1983-01-07	Original certification.