



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 2003888

Master Contract: 151933

Project: 2003888

Date Issued: 2008/06/18

Issued to: Killark Electric Manufacturing Co.

3940 Martin Luther King Dr
St. Louis, MO 63113
USA
Attention: Tom Michalski

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: D. Somma, C.E.T.

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 4418 02 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

CLASS 4418 82 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations -
Certified to US Standards

Class I, Groups B, C, and D; Class II, Groups F and G; Class III, CSA Enclosures 3, 4 and 4X (complete enclosures and component packaged).

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 2003888

Master Contract: 151933

Project: 2003888

Date Issued: 2008/06/18

Outlet boxes Series Cat. B7EP and B7EQ, conduit trade size ½ in through 1-1/2 in NPT or M16 through M40 (US only).

Notes: 1. Series B7EP and B7EQ outlet boxes may be provided with operator holes drilled and tapped in the cover.
2. When conduit openings are not provided at the factory, the enclosures may be provided with field drilling and tapping instructions.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	0-M91	-	General Requirements
CSA Std C22.2 No.	25-1966	-	Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
CSA Std C22.2 No.	30-M1986	-	Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CAN/CSA-C22.2 No.	94-M91	-	Special Purpose Enclosures
Electrical Notice	520	-	CSA Certification of Outlet Boxes for Use in Hazardous Locations, Packaged and Shipped in Component Form
ANSI/UL Standard No.	886	-	Outlet Boxes and Fitting for Use in Hazardous (Classified) Locations
ANSI/UL Standard No.	1203	-	Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations
ANSI/UL Standard No.	50E	-	Enclosures for Electrical Equipment, Environmental Considerations

MARKINGS

Markings shall appear on a metal nameplate, permanently attached to the enclosure by means of drive screws or pins.

- CSA Mark with the c us indicator;
- Company name/logo or CSA File No.
- Hazardous locations designation; (e.g. Cl. I, Gr. B, C and D; Cl. II, Gr. F and G; Cl. III);
- CSA Enclosure Types 3, 4 and 4X;



Certificate: 2003888

Master Contract: 151933

Project: 2003888

Date Issued: 2008/06/18

- Date code/serial number;
- Catalogue number
- Metric Conduit size permanently marked near the connection opening (US only) when metric threaded entries are provided;

CAUTION STATEMENTS (Bilingual optional):

“KEEP COVER TIGHT WHILE CIRCUITS ARE ALIVE” and

“GARDER LE COUVERCLE BIEN FERME TANT QUE LES CIRCUITS SONT SOUS TENSION.”

“COVER JOINTS MUST BE CLEANED BEFORE REPLACING COVER.” and

“LES SURFACES DE CONTACT DU COUVERCLE AVANT DE LE REMETTRE EN PLACE” or equivalent wording.

“A SEAL SHALL BE INSTALLED WITHIN 18 INCHES OF THE ENCLOSURE” and

“UN SCCELLEMENT DOIT ETRE INSTALLE A MOINS DE 18 INCHES DU BOITIER” or equivalent wording.

“CAUTION: THIS COVER IS FOR USE WITH KILLARKS’ OUTLET BOX BODY, P/N _____” and

“ATTENTION: COUVERCLE CONCU POUR ETRE UTILISE AVEC LA BOITE DE SORTIE No _____ FABRIQUEE PAR _____” or equivalent wording.

“CAUTION: THIS OUTLET BOX BODY COVER IS FOR USE WITH KILLARKS’ OUTLET BOX COVER, P/N _____” and

“ATTENTION” BOITE DE SORTIE CONCUE POUR ETRE UTILISEE AVEC LE COUVERCLE No _____ FABRIQUEE PAR _____” or equivalent wording.