



Certificate of Compliance

Certificate: 2003888

Master Contract: 151933

Project: 80066951

Date Issued: 2021-02-26

Issued To: Killark, Div of Hubbell Inc. (Delaware)
2112 Fenton Logistics Park Blvd
Fenton, Missouri, 63026
United States

Attention: Thomas J. Michalski

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Siros Ghanbar-zadeh
Siros Ghanbarzadeh

PRODUCTS

CLASS - C441802 - OUTLET BOXES AND FITTINGS Boxes - For Hazardous Locations

CLASS - C441882 - OUTLET BOXES AND FITTINGS Boxes - For Hazardous Locations - Certified to US Standards

Class I, Groups B, C, and D; Class II, Groups F and G; Class III, CSA Enclosures 3, 4 and 4X

Outlet boxes Series Cat. B7EP and B7EQ, conduit trade size 1/2 in through 1-1/2 in NPT or M16 through M40 (US only).

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No 0-10	General Requirements
CAN/CSA-C22.2 No 25-1966	Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
CAN/CSA-C22.2 No 30-M1986	Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CSA C22.2 No. 94.2:20	Enclosures for electrical equipment, environmental considerations
ANSI/UL Standard No. 886-2005	Outlet Boxes and Fitting for Use in Hazardous (Classified) Locations
ANSI/UL Standard No. 1203 (4 th edition)	Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations



Certificate: 2003888
Project: 80066951

Master Contract: 151933
Date Issued: 2021-02-26

ANSI/UL Standard No. 50E:2020 (3rd edition)	Enclosures for Electrical Equipment, Environmental Considerations
--	---

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Markings shall appear on a metal nameplate, permanently attached to the enclosure by means of drive screws or pins.

- CSA Mark with the c us indicator;
- Company name/logo or CSA File No.
- Hazardous locations designation, Class I, Groups B, C and D; Class II, Groups F and G; Class III,
- CSA Enclosures Types 3, 4 and 4X (where applicable);
- Date code/serial number;
- Catalogue number.
- Metric Conduit size permanently marked near the connection opening (US only) when metric threaded entries are provided;

CAUTION STATEMENTS (Bilingual optional):

“KEEP COVER TIGHT WHILE CIRCUITS ARE ALIVE” and
“GARDER LE COUVERCLE BIEN FERME TANT QUE LES CIRCUITS SONT SOUS TENSION.”

“COVER JOINTS MUST BE CLEANED BEFORE REPLACING COVER.” and
“LES SURFACES DE CONTACT DU COUVERCLE AVANT DE LE REMETTRE EN PLACE” or
equivalent wording.

“A SEAL SHALL BE INSTALLED WITHIN 18 INCHES OF THE ENCLOSURE” and
“UN SCELLEMENT DOIT ETRE INSTALLE A MOINS DE 18 INCHES DU BOITIER” or equivalent
wording.



Supplement to Certificate of Compliance

Certificate: 2003888

Master Contract: 151933

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80066951	2021-02-26	Assessment for update of CSA report 2003888 to include optional enclosure material 413.1. Update to CSA C22.2 N0. 94.2-2020 and ANSI/UL 50E-2020 Third Edition, Enclosures for Electrical Equipment, Environmental Considerations.
0002408503	2011-03-31	Update to Report 2003888 to cover updated drawings and report corrections
0002003888	2008-06-18	Outlet boxes, Series B7EP and B7EQ, with or without operator holes, conduit trade size 1/2 in to 1-1/2 in NPT, for use in Cl. I, Gr. B, C and D; Cl. II, Gr. E, F and G, Cl. III; Types 3, 4 and 4X