



Certificate of Compliance

Certificate: 2054981

Master Contract: 151933

Project: 2408741

Date Issued: March 28, 2011

Issued to: Killark Electric Manufacturing Co.

3940 Dr. Martin Luther King Dr.
St. Louis, MO 63113
USA
Attention: Tom Michalski

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



D. Somma

Issued by: D. Somma, C.E.T.

PRODUCTS

- CLASS 3218 84** - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers-Manual - For Hazardous Locations-Certified to U.S. Standards
- CLASS 3218 04** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Manual - For Hazardous Locations

Class I, Groups B, C, and D; Class II, Groups F and G; Class III; Enclosure Types 3, 4 and 4X

Manual Motor Starters, Series Catalogue: B7MS, B7MSN and B7NFD followed by various numbers and letters to denote electrical and mechanical variations. Rated 600V max, 3 phase 50 HP max; 230 VDC, 2 HP max. Conduit Trade size ½ in through 1-1/2 in NPT and/or M16 through M40 (US only)

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No 0-10 - General Requirements



Certificate: 2054981

Master Contract: 151933

Project: 2408741

Date Issued: March 28, 2011

CAN/CSA-C22.2 No Hazardous Locations	25-1966	-	Enclosures for Use in Class II, Groups E, F and G
CAN/CSA-C22.2 No	14-M95	-	Industrial Control Equipment
CAN/CSA-C22.2 No I,Hazardous Locations	30-M1986	-	Explosion-Proof Enclosures for Use in Class
CAN/CSA-C22.2 No.	94-M91	-	Special Purpose Enclosures
ANSI/UL Standard No. 886 (Classified) Locations		-	Outlet Boxes and Fitting for Use in Hazardous
ANSI/UL Standard No. 1203 Equipment for Use in Hazardous (Classified) Locations		-	Explosion-Proof and Dust-Ignition-Electrical
ANSI/UL Standard No. 50E		-	Enclosures for Electrical Environmental Considerations

MARKINGS

- CSA Mark;
- Company name/logo or CSA File No.
- Hazardous locations designation, Class I, Groups B, C and D; Class II, Groups F and G; Class III;
- Enclosure Types 3, 4 and 4X;
- Date code/serial number;
- Catalogue number
- Metric threaded entries if provided are permanently marked (i.e. M16, M20, M25, M32, or M40)near the supply connection entry.

CAUTION STATEMENTS (Bilingual optional):

“KEEP COVER TIGHT WHILE CIRCUITS ARE ALIVE.”

“GARDER LE COUVERCLE BIEN FERME TANT QUE LES CIRCUITS SONT SOUS TENSION.”

“COVER JOINTS MUST BE CLEANED BEFORE REPLACING COVER.”

“LES SURFACES DE CONTACT DU COUVERCLE AVANT DE LE REMETTRE EN PLACE.”

“A SEAL SHALL BE INSTALLED WITHIN 18 INCHES OF THE ENCLOSURE”

“UN SCELLEMENT DOIT ETRE INSTALLE A MOINS DE 18 INCHES DU BOITIER”.