

CERTIFICATE OF COMPLIANCE

Certificate Number 20180518 – E53290
Report Reference E53290 – 19800324
Issue Date 2018-MAY-18

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS, MO 63113 USA

**This is to certify that
representative samples of**

Enclosed Switches for Use in Hazardous Locations
Enclosed switches (unfused) for use in hazardous locations.

Series DEDS for Class II, Groups E, F and G and Series
XEDS for Class I, groups C and D and Class II, Groups E, F
and G hazardous locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 98, "Enclosed and Dead-Front Switches."
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

