



# Certificate of Compliance

**Certificate:** 70142158 (011713\_C\_000)

**Master Contract:** 151933

**Project:** 70142158

**Date Issued:** 2017-06-29

**Issued to:** Killark Electric Manufacturing Co.  
3940 Dr. Martin Luther King Dr.  
St. Louis, Missouri 63113  
USA

**Attention:** Thomas J. Michalski

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** *Domenic Somma*  
Domenic Somma

## **PRODUCTS**

CLASS - C342803 - FIXTURES AND FITTINGS-For Hazardous Locations

CLASS - C342883 - FIXTURES AND FITTINGS-For Hazardous Locations-Certified to U.S. Standards

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

### **Class I, Division 1, Groups D; Class II, Division 1, Groups E, F and G; Class III; Wet Locations**

- Cat. Nos. EZBA-12, EACH-12, and EACH-16 Cover Adapter for use with specified fixture fittings in conjunction with KILLARK Series EZ, EZL, EMS and EBF fixtures; may be supplied with either Globe or Reflector.

Note: KILLARK EZBA-12, EACH-12, and EACH-16 Adaptors are for use on certified Crouse Hinds Mounting covers Cat. Nos. GUFX-26, EV-22 or EV87 in conjunction with CSA certified Series EZ, EZL, EMS and EBF fixture fittings.

### **Class I, Division 1, Groups C and D; Class II, Division 1, Groups E, F and G; Class III; Wet Locations**

- **Cat. Nos. EAAP-C2** for use with specified fixture fittings in conjunction with KILLARK Series EZ, EZL, EMS and EBF fixtures; may be supplied with either Globe or Reflector.



**Certificate:** 70142158

**Project:** 70142158

**Master Contract:** 151933

**Date Issued:** 2017-06-29

Note: KILLARK EAAP-C2 Series fixture Adaptors are for use on certified Appleton Fixture Mounting Covers Cat. Nos. CAP-75, CAP-100, CAC-75, CAC-100, CALB-75, CALB-100 or CAS-150 in conjunction with CSA Certified EZ, EZL, EMS and EBF fixture fittings.

### **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No	25-1966	- Enclosures for use in Class II, Groups E, F and G Hazardous Locations.
	30-M1986	- Explosion –Proof Enclosures for Use in Class I Hazardous Locations
	94-M91	- Special Purpose Enclosures
	137-M1981	- Electric Luminaires for Use in Hazardous Locations
ANSI/UL Standard	1598 – 3 <sup>rd</sup> Edition	- Luminaires
	1604 – 3 <sup>rd</sup> Edition	- Electrical Equipment for Use in Class I and II, Div. 2, Class III Hazardous Locations
	844 – 12 <sup>th</sup> Edition	- Luminaires for Use in Hazardous (Classified) Locations
	50E – 1 <sup>st</sup> Edition	- Enclosures for Electrical Equipment, Environmental Considerations

### **MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.



**Certificate:** 70142158

**Project:** 70142158

**Master Contract:** 151933

**Date Issued:** 2017-06-29

---

**Nameplate adhesive label material approval information:**

The enclosures are marked with the following information on a certified adhesive label or metal nameplate

- cCSAus Monogram
- Manufacturer's name, trade Mark, File Number or Master Contract Number
- Catalogue Number Designation;
- Enclosure Type Designation;
- Hazardous Location Designation; Equivalent zone markings may be applied
- Date Code or Serial Number;
- May be marked with the words " Suitable for Wet Locations"
- Installation, Operation & Maintenance Data Sheet, Form No. K1483, is provided for EAAP-C2 Adapters;
- Installation, Operation & Maintenance Data Sheet, Form No. K1204, is provides for EACH12, EACH16 & EZBA12 Adapters



## *Supplement to Certificate of Compliance*

**Certificate:** 70142158 (011713\_C\_000)

**Master Contract:** 151933

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>
70142158	2017-06-29	New Project lighting fixture adapters – EZBA-12, EACH-12, EACH-16 and EAAP-C2 for use with specified fixture fittings in conjunction with KILLARK Series EZ, EZL, EMS, EBF and EBF and are for use on certified Crouse Hinds Mounting Covers Cat. Nos. GUFX-26, EV-22 or EV87/ Appleton Fixture Mounting Cat. Nos. CAP-75, CAP-100, CAC-75, CAC-100, CALB-75, CALB-100 or CAS-150 respectively.