



Supplement to Certificate of Compliance

Certificate: 2493135

Master Contract: 151933

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2600645	Mar 20, 2013	Update to report 2493135 to cover revised IOM(Instruction Operation Manual)replace Form K1387 with Form K1392 and revise Form K1388 for Series EBS
2493135	Mar 6, 2012	Explosion-Proof Emergency Battery System Series EBS, rated 277V AC max, 23 W max, for use in Class I, Groups B/C and D; Class II, Groups E, F and G; Class III; Type 4, Temp. Coded T6.