

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170210-E10514  
**Report Reference** E10514-19671003  
**Issue Date** 2017-February-10

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
3940 MARTIN LUTHER KING DR  
ST LOUIS MO 63113

**This is to certify that representative samples of** CONDUIT FITTINGS FOR USE IN HAZARDOUS LOCATIONS  
SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1203: Standard for Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations  
UL 514B: Standard for Conduit, Tubing and Cable Fittings

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE


**Certificate Number** 20170210-E10514  
**Report Reference** E10514-19671003  
**Issue Date** 2017-February-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Series ECF flexible connection fittings, raintight type, for use in the hazardous locations indicated below:

Series ECF, Cat. Nos. ECF-14 to -136 and ECF-24 to -236 flexible connection fittings, conduit sizes 1/2 and 3/4 in., in flexible lengths from 4 to 36 in., for use in Class I, Groups A, \*B, C, and D; Class I, Zone 1, Group IIC and Class II, Groups E, F, and G hazardous locations.

Series ECF, Cat. Nos. ECF-36 to -336 flexible connection fittings, conduit size 1 in., in flexible lengths from 6 to \*36 in., for use in Class I, Groups C and D; Class I, Zone 1, Group IIB and Class II, Groups E, F, and G hazardous locations.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

