## CERTIFICATE OF COMPLIANCE

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)

3940 MARTIN LUTHER KING DR

ST LOUIS MO 63113

This is to certify that CONDUIT FITTINGS FOR USE IN HAZARDOUS LOCATIONS

representative samples of SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203: Standard for Explosion-Proof and Dust-Ignition-Proof

Electrical Equipment for Use in Hazardous (Classified) Locations UL 514B: Standard for Conduit, Tubing and Cable Fittings

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC





## CERTIFICATE OF COMPLIANCE

20170210-E10514 **Certificate Number** E10514-19700310 **Report Reference** 2017-February-10 **Issue Date** 

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Type EKJ, Cat. No. EKJ-4, -5, and -6 flexible connection fittings in lengths from 4 to 36 in., for use in hazardous \*locations, Class I, Groups C and D; Class I, Zone 1, Group IIB and Class II, Groups E, F, and G. The Cat. No. EKJ-6 fitting is also raintight.

Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, p contact a local UL Customer Service Representative at <a href="https://www.ul.com/contactus">www.ul.com/contactus</a>

