

CERTIFICATE OF COMPLIANCE

Certificate Number 20190712-E10514
Report Reference E10514-19820413
Issue Date 2019-JULY-12

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
2112 Fenton Logistics Park Blvd
Fenton MO 63026

**This certificate confirms that
representative samples of**

CONDUIT FITTINGS FOR USE IN HAZARDOUS
LOCATIONS

See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. UL 1203, 5th Ed., Rev. 2019-04-16,
Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190712-E10514
Report Reference E10514-19820413
Issue Date 2019-JULY-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL - Killark Series ENY conduit sealing fittings , for use in Class I, Groups A, B, C and D; Class II, Groups E, F, and G.
Cat. Nos. ENY-1, -1M, -2, -2SET, -2M, -3, -3SET, -3M may be accompanied by T. Conduit sizes 1/2, 3/4, and 1 in.

USL – Killark Series ENY conduit sealing fittings with, for use in Class I, Groups B, C, and D; Class II, Groups E, F, and G.
Cat. Nos. ENY-4, -4M, 5, 5M may be accompanied by T. Conduit sizes 1-1/4, 1 1/2, and 2 in.

USL – Killark Series EY conduit sealing fittings with, for use in Class I, Groups B, C, and D; Class II, Groups E, F, and G.
Cat. Nos. EY-50, EY-50M, EY-75, EY-75M, EY-100, and EY-100M may be accompanied by T.


USL – Killark Series EYD conduit sealing fittings with, for use in Class I, Groups C, and D; Class II, Groups E, F, and G.
Cat. Nos. EYD-50, EYD-50M, EYD-75, EYD-75M, EYD-100, and EYD-100M may be accompanied by T.

Fittings with the suffix “T” are provided with a closed nipple, which can be connected to either end of the fittings.

The devices with suffix “M” are constructed of malleable iron.

No suffix indicates it is constructed out of aluminum.

These fittings are intended for installation in either the horizontal or vertical positions. For use with manufacturer’s “SC” or “KQS” sealing compound and “PF” packing fiber.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

