

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E83969  
**Report Reference** E83969-19871112  
**Issue Date** 2020-FEBRUARY-17

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
2112 FENTON LOGISTICS PARK BLVD  
FENTON, MO 63026 USA

**This is to certify that  
representative samples of**

Enclosures for Use in Hazardous Locations  
Class I, Groups B, C and D; Class II, Groups E, F and G,  
Model(s) EXB(a), EXBLT(a).  
a) - Followed by P or C, followed by three numbers, may be  
followed by -N34, -SPM, -MOD, -N4, -N4X, and/or -N4XTL.

Enclosure may be marked Tam +60°C." And "May be  
marked "Type 3,4,4X.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 1203, 5<sup>th</sup> Edition, Explosion-Proof and Dust-Ignition-  
Proof Electrical Equipment for Use in Hazardous  
(Classified) Locations.  
CSA C22.2 No. 25-M1966, Enclosures for Use in Class II  
Groups E, F, and G Hazardous Locations (R2014).  
CAN/CSA C22.2 No. 30-M1986, Explosion-Proof  
Enclosures for Use in Class I Hazardous Locations

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

