## CERTIFICATE OF COMPLIANCE

 Certificate Number
 20170210-E10514

 Report Reference
 E10514-19641019

 Issue Date
 2017-February-10

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)

3940 MARTIN LUTHER KING DR

ST LOUIS MO 63113

This is to certify that COI representative samples of SFI

CONDUIT FITTINGS FOR USE IN HAZARDOUS LOCATIONS

SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203: Standard for Explosion-Proof and Dust-Ignition-Proof

Electrical Equipment for Use in Hazardous (Classified) Locations UL 514B: Standard for Conduit, Tubing and Cable Fittings

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC





## CERTIFICATE OF COMPLIANCE

Certificate Number 20170210-E10514

Report Reference E10514-19641019

Issue Date 2017-February-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Conduit fittings for sealing, for use in hazardous locations, Class I, Groups C and D; Class I, Zone 1, Group IIB and Class II, Groups E, F, and G, having the following designations and sizes.

Types EY and EYD for vertical mounting only, and for use with manufacturer's sealing compound "Cat. No. SC".

Bambles

Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, pleas contact a local UL Customer Service Representative at <a href="https://www.ul.com/contactus">www.ul.com/contactus</a>

(UL)