

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190712-E10514  
**Report Reference** E10514-19601128  
**Issue Date** 2019-JULY-12

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
2112 Fenton Logistics Park Blvd  
Fenton MO 63026

**This certificate confirms that  
representative samples of**

CONDUIT FITTINGS FOR USE IN HAZARDOUS  
LOCATIONS

See Addendum Page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:**  
**Additional Information:**

ANSI/UL 467, "Grounding and Bonding Equipment."  
See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE


**Certificate Number** 20190712-E10514  
**Report Reference** E10514-19601128  
**Issue Date** 2019-JULY-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Cat. Nos. EYS-1 or -1T, -1M, -1TM, conduit size 1/2 in.; EYS-2 or -2T, -2M, -2TM conduit size 3/4 in.; EYS-3 or -3T, -3M, -3TM, conduit size 1 in.; EYS-4 or -4T, -4M, -4TM, conduit size 1-1/4 in.; EYS-5 or -5T, -5M, -5TM, conduit size 1-1/2 in.; EYS-6 or -6T, -6M, -6TM, conduit size 2 in.; EYS-7 or -7T, -7M, -7TM conduit size 2-1/2 in.; EYS-8, -8M, -8T, -8TM conduit size 3 in. conduit fittings for sealing for use in hazardous locations, Class I, Groups C and D; Class II, Groups E, F and G.

Cat. Nos. EYS-9, -9M, conduit size 3-1/2 in.; EYS-0, -OM conduit size 4 in. conduit fitting for sealing for use in hazardous locations, Class I, \*Group D; and Class II, Groups E, F and G.

Type EYS, for vertical or horizontal mounting, and for use with manufacturer's sealing compound "Cat. No. SC" or "Cat. No. KQS (CELOX)" for up to Size EYS-2.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

