



# Certificate of Compliance

**Certificate:** 2467704

**Master Contract:** 151933

**Project:** 80020066

**Date Issued:** 2020-02-10

**Issued To:** Killark, Div of Hubbell Inc. (Delaware)  
2112 Fenton Logistics Park Blvd  
Fenton, Missouri, 63026  
United States

**Attention:** Brian Pegg

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:**

*Domenic Somma*  
Domenic Somma

## PRODUCTS

### **CLASS 4418 03 – CONDUIT FITTINGS – For Hazardous Locations**

**Class I, Division 1, Groups A, B, C and D; Class II, Div. 1, Groups E, F and G; CSA Enclosure Types 3 and 4:**

- Sealing fittings, for use with Certified sealing compound; EY-50, EY-50M, EY-50T, EY-50TM, EYD-50, EYD-50M, EYD-50T, EYD-50TM, Type EY-75, EY-75M, EY-75T, EY-75TM, EYD-75, EYD-75M, EYD-75T, EYD-75TM, Type EY-100, EY-100M, EY-100-T, EY-100TM, EYD-100, EYD-100M, EYD-100-T, EYD-100TM



**Certificate:** 2467704  
**Project:** 80020066

**Master Contract:** 151933  
**Date Issued:** 2020-02-10

CLASS 4418 83 – CONDUIT FITTINGS – For Hazardous Locations - Certified to US standards  
CLASS 4418 03 – CONDUIT FITTINGS – For Hazardous Locations

**Class I, Division 1, Groups B, C and D; Class II, Div. 1, Groups E, F and G; CSA Enclosure Types 3 and 4:**

- Sealing fittings, for use with Certified sealing compound; Type EY-50, EY-50M, EY-50-T, EY-50-TM, EYD-50, EYD-50M, EYD-50T, EYD-50TM, Type EY-75, EY-75M, EY-75T, EY-75TM, EYD-75, EYD-75M, EYD-75T, EYD-75TM, Type EY-100, EY-100M, EY-100-T, EY-100TM, EYD-100, EYD-100M, EYD-100-T, EYD-100TM

Note:

1. The above sealing fittings are for use with Killark Cat. No “SC” sealing compound or any other CSA/UL certified sealing compounds that are utilized on sealing fittings that are CSA/UL certified for the same Hazardous Location ratings or higher.

**APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No.	0-10	-	General Requirements – Canadian Electrical Code, Part II
	25-18	-	Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
ANSI/UL Standard	30-M1986	-	Explosion-Proof Enclosures for Use in Class I Hazardous Locations.
	94.2	-	Special Purpose Enclosures
	1604	-	Electrical Equipment for Use in Class I and II, Div. 2, Class III Hazardous Locations
	50E-15	-	Enclosures for Electrical Equipment
	1203-2018	-	Explosion-Proof and Dust-Ignition-Proof Electrical Equipment For use in Hazardous (Classified) Locations

**MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.



**Certificate:** 2467704  
**Project:** 80020066

**Master Contract:** 151933  
**Date Issued:** 2020-02-10

---

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

- Manufacturer's name, Trade Mark, File Number or Master Contract Number are integrally cast on the fitting bodies.
- Catalogue number, Hazardous location rating designation, the CSA Monogram with cCSAus indicator are integrally cast on the fitting bodies.
- Instructions for installation of sealing fittings are packaged with the fittings. Included in the instructions is the replacing of drains (Type EYD only) and close-up plugs after installation of the fittings and a minimum ambient temperature below which the seal should not be poured. See K1385 (Series EYD) and K1386 (Series EY) installation instructions.
- The sealing compound container has a label attached which bears the manufacturer's name, the words "Sealing Compound" and the identification "Cat. No. SC" or "KQS".



## *Supplement to Certificate of Compliance*

**Certificate:** 2467704

**Master Contract:** 151933

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80020066	2020-02-10	Update Certificate 2467704 CPB 2520327 to add the new KQS Formula D sealing compound to Series EYD Sealing Fittings.
0002520327	2012-06-08	Update to Certificate 2467704 to cover sealing fitting that were previously certified for Class I, Groups B/ C to upgrade to Class I, Groups A (CSA), B cCSAus
0002467704	2011-12-02	Conduit Fittings, Trade Size 1/2 to 1 in For use in CL. I, Gr. A/B, C and D; CL. II Gr. E, F and G; III; Types 3 and 4