

CERTIFICATE OF COMPLIANCE

Certificate Number 20121001-E10514
Report Reference E10514-20030328
Issue Date 2012-OCTOBER-01

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113.

**This is to certify that
representative samples of**

LUMINAIRE FITTINGS FOR USE IN HAZARDOUS
LOCATIONS; [LUMINAIRES, MARINE] LUMINAIRES,
MISCELLANEOUS, MARINE

See addendum page.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 844 - Luminaires for Use in Hazardous (Classified)
Locations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20121001-E10514
Report Reference E10514-20030328
Issue Date 2012-OCTOBER-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Series EZ fixture fittings for use in Class I, Groups C and D; Class II, Groups E, F and G; and Class III hazardous locations.

Ballast Housing Assemblies - Series EZ followed by M, S or H, followed by 05, 07, 10, 15, 17, 20, 25, or 40 followed by 0, 1, 2, 3, 4, 5, 6, 7, 8 or 9; may be followed by Q, R, BP, and/or PS, and/or F# followed by 1 to 7.

Ballast Housing Assemblies - Series EZ followed by P, followed by 05, 07, 10, 12, 15, 17, 20, 25, 32, 35 or 40 followed by 0, 1, 2, 3, 4, 5, 6, 7, 8 or 9; may be followed by Q, R, BP and/or PS and/or F# followed by 1 to 7.

Splice Boxes - Cat. Nos. EZA2, EZA3, EZX2, EZX3, EZB2, or EZB3.

Optic Assemblies - Cat. Nos. EZGS1 or EZGS2.

Reflectors - Cat. Nos. VMPSD-40, VMPA-40 or HRD-400.

Guards - Cat. Nos. EZG1 or VMAG-40.

Series EZ fixture fittings for use in Class I, Groups C and D hazardous Locations.

Ballast Housing Assemblies - Series EZ followed by M, S, or H followed by 05, 07, 10, 15, 20, 25 or 40 followed by 0 to 9; may be followed by T, R, BP, and/or PS.

Ballast Housing Assemblies - Series EZ followed by P, followed by 05, 07, 10, 12, 15, 20, 25, 32, 35 or 40 followed by 0 to 9; may be followed by T, R, BP, and/or PS.

Splice Boxes - Cat. Nos. EZD4 or EZD5.

These luminaire fittings are also complementary Listed as Miscellaneous Marine Luminaire Fittings (IGZR).

- The F option is for Hazardous Locations coverage only. Luminaires marked for marine shall not be provided with F suffix.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

