



Certificate of Compliance

Certificate: 2166319

Master Contract: 151933

Project: 2166319

Date Issued: 2009/05/19

Issued to: Killark Electric Manufacturing Co.

3940 Martin Luther King Dr
St. Louis, MO 63113
USA

Attention: Thomas J. Michalski

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: D. Somma, C.E.T.

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 4418 83 - CONDUIT FITTINGS - Fittings - For Hazardous Locations - Certified to US Standards

CLASS 4418 03 - CONDUIT FITTINGS - Fittings - For Hazardous Locations

Class I, Div. 1, Groups A, B, C and D; Class II, Div. 1, Groups E, F and G; Class III:



Certificate: 2166319

Master Contract: 151933

Project: 2166319

Date Issued: 2009/05/19

Conduit elbows, 45 – deg bend, Cat. No. FF-45-8 & FF-45-8M, conduit size 3 in.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No 0-M - General Requirements - Canadian Electrical Code, Part II

CAN/CSA-C22.2 No 30-M198 - Explosion-Proof Enclosures for Use in Class I, Hazardous Location

CAN/CSA-C22.2 No 25-1966 - Enclosure for use in Class II, Groups E, F and G;

Hazardous Locations

ANSI/UL - 1203 Fourth Ed. - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

MARKINGS

The following markings are stamped into the conduit fittings:

- Submitter's name or trade Mark;
- Catalogue number or Type Designation;
- Hazardous Locations Designation;
- CSA Monogram (cCSAus)