

CERTIFICATE OF COMPLIANCE

Certificate Number 20161004-E12379
Report Reference E12379-19870911
Issue Date 2016-OCTOBER-04

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

**This is to certify that
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS
LOCATIONS

See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations
CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class
II Groups E, F, and G Hazardous Locations
CAN/CSA C22.2 No. 30-M1986, Explosion-Proof
Enclosures for Use in Class I Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20161004-E12379
Report Reference E12379-19870911
Issue Date 2016-OCTOBER-04


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL - Open type auxiliary device Series GO6, GO7, GO8, GO14, GO15, GO36, GO37, GO38, GO39, GOL6, GOL7, GOL8, GOL14, GOL15, GOL36, GOL37, GOL38, GOL39, selector switches followed by additional suffix letters and numbers. GO devices with N34 suffix and all GOL devices are for use in environmental Types 3, 3R, 3S, 4 and 4X and wet locations. These are control devices for use in Class I, Groups B, C and D; Class II, Groups E, F and G.

Series GO26, GO27, GO28, GO56, GO57, GO58, GO59 selector switches followed by additional suffix letters and numbers for use in Class I, Groups C and D; Class II, Groups E, F and G Hazardous Locations.

Series GO113, GO114, GOL113 & GOL114 rotary operators for potentiometers. GO devices with N34 suffix and all GOL devices are for use in environmental Types 3, 4 and 4X enclosures. These devices are for use in Class I, Groups B, C and D; Class II Groups E, F and G; Class III Hazardous Locations.

Series GO133 and GO134 rotary operators for potentiometers for use in Class I, Groups C and D; Class II, Groups E, F and G; Class III Hazardous Locations.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

