

CERTIFICATE OF COMPLIANCE

Certificate Number 20161004-E12379
Report Reference E12379-19870910
Issue Date 2016-OCTOBER-04

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

**This is to certify that
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS
LOCATIONS

USL, CNL - Open type auxiliary devices, Series G021
single push button station, Series G022 double push button
station, Series G025 maintained contact selector switch,
Series G08 key-operated selector switch and Series G028
key-operated selector switch and series GOM21 push/pull
mushroom maintained push button for use in Class I,
Groups C and D; Class II, Groups E, F and G Hazardous
Locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations
CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class
II Groups E, F, and G Hazardous Locations
CAN/CSA C22.2 No. 30-M1986, Explosion-Proof
Enclosures for Use in Class I Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

