

CERTIFICATE OF COMPLIANCE

Certificate Number 20130626-E53360
Report Reference E53360-19740913
Issue Date 2013-JUNE-26

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

**This is to certify that
representative samples of**

CONTROL PANELS AND ASSEMBLIES FOR USE IN
HAZARDOUS LOCATIONS

Modular control assemblies, Series GCS, -1 through -21, -31 through -38, -41 through -46, -48 through -49, 152 and 163, for use in hazardous locations, Class I, Groups C and D, Class II, Groups E, F, and G, and Class III, consisting of push-button stations, pilot lamps, selector switch, and knob or key-operated selector switches housed in a multigang enclosure

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203 - Standard For Explosion-Proof And Dust-Ignition-Proof Electrical Equipment For Use In Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

