

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.lecex.com

Certificate No.:

IECEx SIR 12.0107

issue No.:1

Certificate history: Issue No. 1 (2014-8-1)

Issue No. 0 (2013-4-29)

Status:

Current

Date of Issue:

2014-08-01

Page 1 of 5

Applicant:

Killark, A Div. of Hubbell Inc. (Delaware)

3940 Martin Luther King Drive

St. Louis Missouri 63113

United States of America

Electrical Apparatus: Optional accessory:

GEB Junction Boxes

Type of Protection:

Flameproof and Dust

Marking:

Ex d IIC T* Gb Ex t IIIC T**°C Db Ta = -40°C to +***°C

Refer to Equipment for ,T*, T**, Cable entry, Ambient Range ***.

Approved for issue on behalf of the IECEx

Certification Body:

A C Smith

Position:

Certification Manager

Signature: (for printed version)

Date:

2014-08-01

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

SIRA Certification Service Rake Lane Eccleston Chester CH4 9JN United Kingdom







Certificate No.:

IECEx SIR 12.0107

Date of Issue:

2014-08-01

Issue No.: 1

Page 2 of 5

Manufacturer:

Killark, A Div. of Hubbell Inc. (Delaware)

3940 Martin Luther King Drive

St. Louis Missouri 63113

United States of America

Additional Manufacturing location

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition: 6.0

IEC 60079-1: 2007-04

Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"

Edition: 6

IEC 60079-31 : 2008

Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure 't'

Edition: 1

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/SIR/ExTR13.0085/01

Quality Assessment Report:

US/UL/QAR07.0004/04



Certificate No.:

IECEx SIR 12.0107

Date of Issue:

2014-08-01

Issue No.: 1

Page 3 of 5

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

Marking (continued)

Power	Ambient, Ta & Cable entry				
(W)	T6/T85°C	T5/T100°C	T4/T135°C	T3/T200°C	
20	Ta 48°C	Ta 63°C	Ta 98°C	Ta 163°C	
	Cable entry; 79°C	Cable entry; 94°C	Cable entry; 129°C	Cable entry; 194°C	
30	N/A	Ta 50°C	Ta 85°C	Ta 150°C	
		Cable entry; 92°C	Cable entry; 127°C	Cable entry; 191°C	
40	N/A	Ta 38°C	Ta 73°C	Ta 138°C	
		Cable entry; 91°C	Cable entry; 126°C	Cable entry; 190°C	

Refer to EQUIPMENT (continued) for equipment description.

CONDITIONS OF CERTIFICATION: NO

П				
-				
-				
-				
-				
-				
-				
-				
-				
-				
111				
ш				
ш				
-				
-				
111				
11				
11				
П				
П				
П				
I				
I				



Certificate No.:

IECEx SIR 12.0107

Date of Issue:

2014-08-01

Issue No.: 1

Page 4 of 5

EQUIPMENT(continued):

The GEB Junction Boxes utilise the GEB Enclosure, certified under IECEx SIR 12.0106U which is constructed from cast aluminium alloy and comprises a cylindrical base and threaded cover assembly, secured via a set screw. The GEB range of enclosures have up to five conduit openings, in entry sizes detailed as follows:

Entry size	
NPT	Metric
1/2"-14	M20x1.5
3/4"-14	M25x1.5
1"-11 1/2	M32x1.5
1-1/4"-11 1/2	M40x1.5
1-1/2" -11 1/2	M50x1.5

The GEB Junction Boxes are fitted with terminal blocks and have a minimum internal free volume of 190 cm³ when populated.

Suitably certified Ex d IIC Gb/Ex t IIIC Db (minimum) entry devices suitable for an ambient temperature range as marked, may be fitted.

Internal earth facilities and external earth bonding is via internal/external screw and split lock washer assemblies.

The GEB Junction Boxes have an IP 66 ingress protection rating in accordance with IEC 60529



Certifi	cata	Nic	٠.
Cettii	ıcale	INC	J. :-

IECEx SIR 12.0107

Date of Issue:

2014-08-01

Issue No.: 1

Page 5 of 5

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Issue '	1 – this Issue introduced the following changes: Issued to allow GB/SIR/ExTR13.0085/01 to replace GB/SIR/ExTR13.0085/00
1	Issued to allow GB/SIR/ExTR13.0085/01 to replace GB/SIR/ExTR13.0085/00