



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1820607

Master Contract: 151933

Project: 1820607

Date Issued: 2006/09/21

Issued to: Killark Electric Manufacturing Co.

3940 Martin Luther King Dr
St. Louis, MO 63113
USA

Attention: Mr. Thomas J. Michalski

The products listed below are eligible to bear the CSA Mark shown



Issued by: Mr. D. Somma, C.E.T.

Authorized by: Patricia Pasemko, Operations
Manager

PRODUCTS

CLASS 4418 02 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

Class I, Groups B, C, and D; Class II, Groups E, F and G; Class III, CSA Enclosures 3, 4 and 4X

• Series GEB – Types GEBC, GEBL, GEBT, and GEBX, followed by -2, -3, -4, -5, -24, or -25, conduit size 3/4 to 1-1/2 in

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 25-1966 Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 Explosion-Proof Enclosures for Use in Class I Hazardous Locations



Certificate: 1820607

Master Contract: 151933

Project: 1820607

Date Issued: 2006/09/21

CAN/CSA C22.2 No. 94-M91 Special Purpose Enclosures

MARKINGS

The equipment is marked with the following information.

The below markings shall be embossed, stamped, cast or molded in the enclosure where it is readily visible after installation. As an option, the information maybe provided on a metal nameplate secured to the enclosure by drive pins or screws into bottomed holes.

- CSA Mark;
- Manufacturer's name, Trade Mark, File Number or Master Contract Number
- Hazardous locations designation, Class I, Groups B, C and D; Class II, Groups E, F and G; Class III (May be optionally marked with the addition of Zone markings – Class I, Zone 1, Groups IIB+H2, IIB and IIA)
- Enclosure Types 3, 4 and 4X
- Part Number on the Body and Cover
- Caution statements: (French Equivalent when applicable):

“CAUTION: To Prevent Ignition Of Hazardous Atmosphere Disconnect From Supply Circuits Before Opening. Keep Cover Tight While Circuits Are Alive”

“Warning: To Reduce The Risk Of Ignition Of Hazardous Atmospheres, Conduit Runs Must Have a Sealing Fitting Connected Within 24 in. of the Enclosure.”