

CERTIFICATE OF COMPLIANCE

Certificate Number 20160912-E10514
Report Reference E10514-19691217
Issue Date 2016-SEPTEMBER-12

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

This is to certify that representative samples of OUTLET BOXES FOR USE IN HAZARDOUS LOCATIONS
SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 1203, "Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations" and ANSI/UL 50, "Enclosures for Electrical Equipment"

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160912-E10514
Report Reference E10514-19691217
Issue Date 2016-SEPTEMBER-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL - Conduit boxes for use in hazardous locations, Class I, Groups C and D, and Class II, Groups E, F, and G.


Series GE(+) - Types GEC, GEUE, GEUEA, and GEUU, with integral unions, conduit size 1/2 or 3/4 in.

USL - Conduit boxes for use in hazardous locations, Class I, Groups B, C and D, Class II, Groups E, F, and G, and Class III.

Series GEC(+) - Types GECMA, GECME, GECMU, GECTM, GECUE, and GECUU, integral unions, conduit size 1/2 or 3/4 in. Types GECUET and GECUWT, with threaded hubs, conduit size 1/2 or 3/4 in.

(+) The device catalog number consists of the type designation followed by suffix number -1 for 1/2 in. conduit size, or -2 if for 3/4 in. conduit size. Cat. Nos. may be followed by the letter M to denote ductile iron.

The GEC Series may also be marked "Type 3/4/4X" or "Type 4X"



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

