

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190502-E10514  
**Report Reference** E10514-19601223  
**Issue Date** 2019-MAY-02

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
3940 MARTIN LUTHER KING DR  
ST LOUIS MO 63113

**This certificate confirms that representative samples of** OUTLET AND JUNCTION BOXES FOR USE IN HAZARDOUS LOCATIONS

Refer Addendum page for Models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations  
UL 50, Enclosures for Electrical Equipment, Non-Environmental Considerations

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190502-E10514  
**Report Reference** E10514-19601223  
**Issue Date** 2019-MAY-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Conduit boxes for use in Hazardous Locations, Class I, Group D and Class II, Groups E, F, and G with designations and conduit sizes indicated below.

Series GEJ conduit boxes, conduit sizes 1-1/2 and 2 in. The catalog numbers of the devices are given in Fig. 1. The Cat. Nos. maybe followed by the letter M to denote ductile iron bodies and aluminum covers. If no suffix is used, both the cover and body are aluminum.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

