

CERTIFICATE OF COMPLIANCE

Certificate Number 20161004-E12379
Report Reference E12379-19851121
Issue Date 2016-OCTOBER-04

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

**This is to certify that
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS
LOCATIONS

Open type auxiliary device Series GOB4 and GOL4 push
button pilot light combination for use in Class I, Groups B, C
and D, Class II, Groups E, F and G hazardous locations.

Cat. Nos. GOB4 or GOL4; followed by A, B, C, F, G or R;
followed by 1, 2, 4, 5, 7, 8 or 23; followed by 1, 2, 3, 4,
5, 6, 7 or 8; followed by C; followed by N34 (Series GOB4
only).

Series GOB4 with -N34 suffix and Series GOL4 devices are
for use in environmental Type 3, 3R, 3S, 4 and 4X and wet
locations.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

