

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160912-E10514  
**Report Reference** E10514-19950623  
**Issue Date** 2016-SEPTEMBER-12

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
3940 MARTIN LUTHER KING DR  
ST LOUIS MO 63113

**This is to certify that representative samples of** OUTLET BOXES FOR USE IN HAZARDOUS LOCATIONS  
See addendum page for models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 1203, "Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations" and ANSI/UL 50, "Enclosures for Electrical Equipment"

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160912-E10514  
**Report Reference** E10514-19950623  
**Issue Date** 2016-SEPTEMBER-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Series GR outlet boxes for use in Class I, Groups B, C and D; Class II, Groups E, F and G Hazardous Locations.


Cat. No. GRB may be prefixed by 2 or 4, followed followed by P; Cat. No. GRE followed by P; Cat. No. GRK may be prefixed by 4, followed by P; cat. No. GRM may be prefixed by 3 or 5, followed by P; Cat. No. GRL followed by P; Cat. No. GRH may be prefixed by 4 or 8, followed by P; Cat. No. GRHA may be prefixed by 4 or 8, followed by P; Cat. No. GRHC may be prefixed by 4 or 8, followed by P. All may have suffixes SU3B, SU6, SU8, SU9, SU10B, SU11B, SU14 and -CEN.

Series GR outlet boxes for use in Class I, Groups C, and D; Class II, Groups E, F and G Hazardous Locations.

Cat. No. GRB may be prefixed by 2 or 4, followed by P; Cat. No. GRE followed by P; Cat. No. GRK may be prefixed by 4, followed by P; Cat. No. GRM may be prefixed by 3 or 5, followed by P; Cat. No. GRL followed by P; Cat. No. GRH may be prefixed by 4 or 8, followed by P; Cat. No. GRHA may be prefixed by 4 or 8, followed by P; Cat. No. GRHC may be prefixed by 4 or 8, followed by P. All may have suffixes SU3, SU10, SU11 and -CEN.

Cat. No. (+)	Maximum Conduit Size	
	NPT	Metric
GRB	2	M63
GRE	2	M63
GRK	2-1/2	M63
GRM	3	M63
GRL	2-1/2	M63
GRH	4	M63
GRHA	4	M63
GRHC	4	M63

(+) - Except when Suffix SU3B, SU3, SU10B, SU10, SU11B and SU11 are specified the outlet boxes may be marked enclosure Type 3, 4 and 4X.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

