

CERTIFICATE OF COMPLIANCE

Certificate Number 20160912-E10514
Report Reference E10514-19690124
Issue Date 2016-SEPTEMBER-12

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

**This is to certify that
representative samples of**

OUTLET BOXES FOR USE IN HAZARDOUS LOCATIONS
Conduit boxes for use in hazardous locations, Class I,
Groups C and D, and Class II, Groups E, F and G with
designations given below:
GRSS-1, -1M GRSSA-1, -1M, GRSS-3, -3M
GRSSA-1, -1M, -2, -2M

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 1203, "Explosion-Proof and Dust-Ignition-Proof
Electrical Equipment for Use in Hazardous (Classified)
Locations" and ANSI/UL 50, "Enclosures for Electrical
Equipment"

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

