

CERTIFICATE OF COMPLIANCE

Certificate Number E12379
Report Reference E12379-20150124
Issue Date 2020-SEPTEMBER-04

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
2112 Fenton Logistics Park Blvd
Fenton MO 63026

**This certificate confirms that
representative samples of** AUXILIARY DEVICES FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS
Pilot Light, Type HKHPLP and HKHPLD for use in Class I,
Zone 1, AEx db eb IIC Gb and Ex db eb IIC Gb Hazardous
Locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page for Standards
Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number	E12379
Report Reference	E12379-20150124
Issue Date	2020-SEPTEMBER-04

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standards for Safety:

UL 60079-0, Explosive atmospheres – Part 0: Equipment – General requirements.

UL 60079-1, Explosive Atmospheres – Part 1: Equipment Protection by Flameproof Enclosures “d”.

UL 60079-7, Explosive Atmospheres – Part 7: Equipment protection by increased safety “e”.

CSA C22.2 No. 60079-0:19, Explosive atmospheres – Part 0: Equipment – General requirements.

CAN/CSA-C22.2 No. 60079-1:16, Explosive atmospheres — Part 1: Equipment protection by flameproof enclosures “d”.

CAN/CSA-C22.2 No. 60079-7:16, Explosive atmospheres — Part 7: Equipment protection by increased safety “e”.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

