

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E10514  
**Report Reference** E10514-19690128  
**Date** 2020-November-16

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
2112 Fenton Logistics Park Blvd  
Fenton MO, 63026 US

**This is to certify that  
representative samples of**

OUTLET AND JUNCTION BOXES FOR USE IN  
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1203 Explosion-Proof and Dust-Ignition-Proof Electrical  
Equipment for Use in Hazardous (Classified) Locations

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E10514  
**Report Reference** E10514-19690128  
**Date** 2020-November-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Series JL and JAL conduit boxes for use in hazardous locations, Class I, Groups C and D, and Class II, Groups E, F, and G, having the designations given below.

Series JL, Cat. Nos. JLC, JLE, JLL, JLT, and JLX, followed by -10 or -20; threaded for rigid conduit, 1 1/2 and 3/4 in. conduit sizes.

Series JAL, Cat. Nos. JALC, JALE, JALL, JALT and JALX, \* followed by -10, -20 or -30; threaded for rigid conduit, 1/2, 3/4 and 1 in. conduit sizes.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

