

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170606-E10514  
**Report Reference** E10514-19900813  
**Issue Date** 2017-JUNE-06

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
3940 MARTIN LUTHER KING DR  
ST LOUIS MO 63113

**This is to certify that  
representative samples of**

CONDUIT FITTINGS FOR USE IN HAZARDOUS LOCATIONS  
USL - Cat. No. KB1, may be followed by B or D, may be followed by additional numbers and/or letters. 1/2 in. conduit size, conduit fitting for draining or venting, for use in hazardous locations, Class I, Groups B, C and, D; and Class II, Groups E, F and G.

Cat. No. KB1-4X, may be followed by additional numbers and/or letters. 1/2 in. conduit size, conduit fittings for draining and venting, for use in hazardous locations, Class I, Groups B, C and, D; and Class II, Groups E, F and G. Rated Type 3/4/4X.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations  
UL 50E - Enclosures for Electrical Equipment, Environmental Considerations

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

