

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170606-E10514  
**Report Reference** E10514-19680104  
**Issue Date** 2017-JUNE-06

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
3940 MARTIN LUTHER KING DR  
ST LOUIS MO 63113

**This is to certify that  
representative samples of**

CONDUIT FITTINGS FOR USE IN HAZARDOUS  
LOCATIONS

Catalog No. KDB-1, 1/2 in. conduit size, conduit fitting for  
draining or venting, for use in hazardous locations, Class I,  
Groups C and D; Class I, Zone 1, Group IIB and Class II,  
Groups E, F and G.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

Standard No. UL 1203, Explosion-Proof and Dust-Ignition-  
Proof Electrical Equipment for Use in Hazardous  
(Classified) Locations  
Standard No. UL 50 E, Enclosures for Electrical Equipment,  
Environmental Considerations

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

