

CERTIFICATE OF COMPLIANCE

Certificate Number 20130626-E53360
Report Reference E53360-19890421
Issue Date 2013-JUNE-26

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

**This is to certify that
representative samples of**

CONTROL PANELS AND ASSEMBLIES FOR USE IN
HAZARDOUS LOCATIONS

Refer addendum page for models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:

Standard for Non-incendive Electrical Equipment for Use in
Class I, and II, Division 2 and Class III, Divisions 1 and 2
Hazardous (Classified) Locations, ANSI/ISA 12.12.01-2011

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130626-E53360
Report Reference E53360-19890421
Issue Date 2013-JUNE-26

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL Class I, Division 2, Groups A, B, C, and D

Modular Control Panels consisting of Series PWB boxes and Series D2C cover assemblies for use in hazardous locations as follows:

Modular Control Bodies (Boxes), Cat. No. PWB followed by letters and numbers

Modular Control Covers, with Pilot lights, pushbuttons and selector switches, Cat. Nos. D2C; followed by additional letters and/or numbers



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

