

Certificate of Compliance

Certificate: 2218704 Master Contract: 151933

Project: 70022079 **Date Issued:** May 4, 2015

Issued to: Killark Electric Manufacturing Co.

3940 Dr. Martin Luther King Dr.

St. Louis, Missouri 63113

USA

Attention: Thomas J. Michalski

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by:

Joe da Silva, C.E.T.

for de lie

PRODUCTS

CLASS - C623803 - RECEPTACLES-Attachment Plug Type and Plugs - With Switch - For Hazardous CLASS - C623883 - RECEPTACLES-Attachment Plug Type and Plugs-With Switch-For Hazardous Locations-Certified to U.S. Standards

Class I, Groups B, C, and D; Class II, Groups F (Coal or Coke Dust) and G, Types 3 and 4

Series UGRP Acceptor Panel Receptacle, Model Numbers UGRP-15231B, UGRP-15231F, UGRP-15232B, UGRP-15232F, UGRP-20231B, UGRP-20231F, UGRP-20232B, UGRP-20232B, UGRPC-20231B, UGRPC-20232B, UGRPC-20232F.

Electrical Ratings

<u>Suffix</u>	<u>Ratings</u>
-15231B, 15231F	15A, 125 volt, 1HP
-20231B, 20231F	20A, 125 volt, 1HP
-15232B, 15232F	15A, 250 volt, 2HP
-20232B, 20232F	20A, 250 volt, 2HP

Class I, Div. 2, Groups B, C, and D; Class II, Groups F (Coal or Coke Dust) and G,

DQD 507 Rev. 2012-05-22 Page 1



 Certificate:
 2218704
 Master Contract:
 151933

 Project:
 70022079
 Date Issued:
 May 4, 2015

Series UGRS Acceptor Panel Receptacle, Model Numbers UGRS-15231B, UGRS-15231F, UGRS-15232B, UGRS-15232F, UGRS-20231B, UGRS-20231F, UGRS-20232F, UGRSC-20231B, UGRSC-20231F, UGRSC-20232B, UGRSC-20232F.

Electrical Ratings

<u>Suffix</u>	<u>Ratings</u>
-15231B, 15231F	15A, 125 volt, 1HP
-20231B, 20231F	20A, 125 volt, 1HP
-15232B, 15232F	15A, 250 volt, 2HP
-20232B, 20232F	20A, 250 volt, 2HP

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No 0-M91 CAN/CSA - C22.2 No. 25 - 1966

CAN/CSA-C22.2 No C22.2 No 30-M1986

CAN/CSA-C22.2 No C22.2 No.94-M91 CAN/CSA-C22.2 No C22.2 No.159-M1987

CAN/CSA-C22.2 No. 213-M1987

Electrical Notice No.336

UL 50 11th Ed ANSI/UL 1203, 5th Ed

ANSI/ISA-12.12-01-2013

- General Requirements
- Enclosures for use in Class II, Groups E, F and G hazardous locations
- Explosion-Proof Enclosures for use in Class I Hazardous Locations
- Special Purpose Enclosures
- Attachment Plugs, Receptacles, and Similar Wiring
- Devices for Use in Hazardous Locations: Class I, Groups A, B, C, and D; Class II, Group G, in Coal and Coke Dust, and in Gaseous Mines
- Non-incendive electrical equipment for use in Class I, Div. 2 Hazardous Locations
- CSA Certification of Small Motor Control Devices, Light Switches and Other Similar Devices for Use in Class I Hazardous Locations, Shipped in Component Form
- -Enclosures for Electrical Equipment,
- Explosion-Proof and Dust-Ignition-Proof Electrical Equipment For use in Hazardous (Classified) Locations
- Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.

DQD 507 Rev. 2012-05-22 Page 2



Supplement to Certificate of Compliance

Certificate: 2218704 (014667_C_000) **Master Contract:** 151933

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70022079	May 4 2015	CSA c-us certification of UGRS Series Square Flange 15A and 20A Panel Mount Receptacles for use in Hazardous Locations.
70025861	Mar 23 2015	Update report 2218704 to add 15A and 20A (Non T-Slot) part numbers
2218704	Feb 1 2010	Acceptor Panel Recepatacle rated 20 A max, 250 Vmax, for use in Class I, Div. 1, Groups B, C and D; Class II, Groups F(Coal and Coke Dust) and G

DQD 507 Rev. 2012-05-22 Page 1