

CERTIFICATE OF COMPLIANCE

Certificate Number E10514
Report Reference E10514-20210428
Date 2021-May-11

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
2112 Fenton Logistics Park Blvd
Fenton MO, 63026 US

**This is to certify that
representative samples of**

CONDUIT FITTINGS FOR USE IN HAZARDOUS
LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: SEE ADDENDUM PAGE

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E10514
Report Reference E10514-20210428
Date 2021-May-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL, CNL – Conduit unions for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III hazardous locations

Cat. Nos. UNF and UNY, followed by 50, 50AL, 75, 100, or 125.

USL, CNL – Conduit unions for use in Class I, Groups C and D; Class II, Groups E, F and G; Class III hazardous locations

Cat. Nos. UNF and UNY, followed by 75AL, 100AL, 125AL, 150, 150AL, 200, 200AL, 250, 250AL, 300, 300AL, 350, 350AL, 400 or 400AL.

Standard(s) for Safety:


UL 1203 Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.

UL 50E Electrical Equipment Environmental Consideration.

CSA C22.2 No. 94.2-15 Enclosures for electrical equipment, environmental considerations.

CSA C22.2 No. 25-17 Enclosures for use in Class II, Groups E, F and G Hazardous Locations.

CSA C22.2 No. 30: 20 Explosion-Proof equipment.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

