

CERTIFICATE OF COMPLIANCE

Certificate Number 20151102-E184637
Report Reference E184637-20020826
Issue Date 2015-NOVEMBER-02

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR ST LOUIS MO 63113

**This is to certify that
representative samples of**

RECEPTACLE-ENCLOSURE COMBINATIONS WITH
PLUGS FOR USE IN HAZARDOUS RECEPTACLE-
ENCLOSURE COMBINATIONS WITH PLUGS FOR USE
IN HAZARDOUS

Cat. Nos. VSQ6023 and VSQ6034, may be followed by FS,
receptacle-enclosure combination for use in
Class I, Groups B, C and D; Class II, Groups F and G;
Class III hazardous locations. Enclosure Type designations of
Type 3, 4 and 4X.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1010 Receptacle-Plug Combinations for use in Hazardous
(Classified) Locations
UL 1203 Explosion-Proof and Dust-Ignition Proof Electrical
Equipment for Use in Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

