



Certificate of Compliance

Certificate: 2687222 (LR 111846)

Master Contract: 151933

Project: 2687222

Date Issued: June 20, 2014

Issued to: Killark Electric Manufacturing Co.

3940 Dr. Martin Luther King Dr.

St. Louis, MO 63113

USA

Attention: Brian Pegg

The products listed below are eligible to bear the CSA Mark shown



Alejandra Gonzalez

Issued by: Alejandra Gonzalez

PRODUCTS

CLASS 6233 06 - RECEPTACLES - Pin-and-Sleeve Type Plugs and Receptacles

Electrical Ratings: 150 Amp, 600VAC 50-400Hz, 250VDC; rated for use with cord Types G, W, S, SO, STO and Enclosure Type 3, 4, and 4X

- Plugs; Cat. Nos. VPA15034, VPA15044, VPC15034, and VPC15044, optionally followed by suffix –S37 and/or –S39.
- Receptacles; Cat. Nos. VRA15034, VRA15044, VRC15034, and VRC15044, may be followed by Suffix –S37. VRA15034-S37, VRA15044-S37, VRC15034-S37 and VRC15044-S37, may be followed by Suffix –S39.
- Connectors; Cat. Nos. VCA15034, VCA15044, VCC15034, and VCC15044, optionally followed by suffix –S37 and/or –S39.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0.4-04 – Bonding of Electrical Equipment

CAN/CSA-C22.2 No. 94-M91 – Special Purpose Enclosures

CAN/CSA-C22.2 No. 182.1 – 07 – Plugs, Receptacles, and Cable Connectors of the Pin and Sleeve Type



Supplement to Certificate of Compliance

Certificate: 2687222

Master Contract: 151933

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2687222	Jun 20, 2014	Original Certification of Versamate 150A Plugs, Cord Connectors and Receptacles