

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20161004-E12379  
**Report Reference** E12379-19770404  
**Issue Date** 2016-OCTOBER-04

**Issued to:** KILLARK, DIV OF HUBBELL INC (DELAWARE)  
3940 MARTIN LUTHER KING DR  
ST LOUIS MO 63113

**This is to certify that  
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS  
LOCATIONS

Cat. No. XMSW manual motor controllers with thermal over-  
load protection and Cat. No. XMSW manual motor  
controller enclosures, for use in hazardous locations Class  
I, Groups C and D, and Class II, Groups E, F and G.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical  
Equipment for Use in Hazardous (Classified) Locations.

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

