



QPS Evaluation Services Inc
Testing, Certification and Field Evaluation Body
Accredited in Canada, the USA, and Internationally

Page 1 of 2

File
LR3251

CERTIFICATE OF COMPLIANCE
(ISO TYPE 3 CERTIFICATION SYSTEM)

Issued to	Killark - A Division of Hubbell Inc.		
Address	2112 Fenton Logistics Park Blvd. Fenton, MO 63026 USA		
Project Number	LR3251-2		
Product	LED Luminaires for use in Ordinary locations with optional Battery Backup, Reflectors (Domed type and Angle)		
Model Number	WMBLX Series, and Reflectors (Domed type and Angle). *WMBLX Series is followed by alphanumeric suffixes denoting electrical and mechanical variations. (See Nomenclature breakdown below)		
Ratings	Input: 120-277 VAC 50/60Hz, 377-480 Vac 50/60Hz, 105-250 Vdc		
Environmental ratings	Type 4X enclosure, IP 66, Marine Rated (US Only) T _{amb} : -40°C to 55°C (Standard Version). T _{amb} : -20°C to 40°C (Battery Backup Version)		
Applicable Standards	Standard Number	Edition	Date
	CAN/CSA-C22.2 No. 250.0-17	5 th	2017
	CAN/CSA-C22.2 No. 94.2	2 nd	2015
	CAN/CSA-C22.2 No. 250.13:20	--	2020
	UL 50E	2020	2020
	UL 1598	5 th	2021
	UL 1598A	1 st	2000
	UL 8750	2 nd	2021
	ANSI/IEC 60529:2004	R2011	2011
Factory/Manufacturing Location	Killark - A Division of Hubbell Inc. 2112 Fenton Logistics Park Blvd., Fenton, MO 63026 USA		

Statement of Compliance: The product(s)/equipment identified in this Certificate and described in the Report covered under the above referenced project number have been investigated and found to be compliant with the relevant requirements of the above referenced standard(s) and versions. As such, they are eligible to bear the QPS Certification Mark shown below, in accordance with the provisions of QPS's Service Agreement.

IMPORTANT NOTE

In order to maintain integrity of the QPS Mark(s), this certification will be revoked if:

- (1) Compliance with the above-mentioned Standard(s) – including any, informed through QPS Standard Update Notice (QSD 55) issued in future – is not maintained, or
- (2) The product/equipment is modified after certification is granted, without prior written consent from QPS.



Issued By: Scott Airdrie

Signature: *Scott Airdrie*

Date: March 28, 2025



QSD 34

The SCC and IAS Accreditation Symbols are official symbols of the respective accreditation bodies, used under license.

81 Kelfield St., Unit 8, Toronto, ON, M9W 5A3, Canada Tel: 416-241-8857; Fax: 416-241-0682

www.qps.ca



Rev 05



YYZZ – White LED Chromaticity where
YY= correlated color temperature (CCT) minimum 3000K;
ZZ= Color Rendering Index (CRI) maximum 95
(No value=Standard 5000K CCT 70 CRI minimum)
AR – Angled Reflector (MBLXAR)
DR – Dome Reflector (MBLXDR)
SP – Add Supplemental Surge Protection
TBx -- Terminal Blocks (may be alphanumeric to indicate terminals)
xH – Optional Paint (i.e. RH = Red Housing)
Guard
G – With Guard
N – No Guard