

**REPORT
 of
 RECLOSER CONTROLLER SIMULATED SURGE ARRESTER
 OPERATION TEST**

A- Beckwith 32pin design

SPECIMEN DESCRIPTION

Recloser Control:	Beckwith 32pin		
Control Part #	M7679-V6L1ML6ELT2C0000 / M-2979-A32B01DW109SUTY0		
Control Serial #	1091		
Three-phase Recloser:	G&W Viper ST Type VIP388ER-12-1-ST		
Impulse level (BIL):	125 kV _{peak}		
Rated Voltage:	27 kV _{rms}		
Rated Current:	800 A _{rms} continuous		
Viper ST Serial No.:	2016 0824 0049		
Reference drawing: N.A.	Photographs attached:	Yes: X	No:

Dates of Test: 14-December-2016 through 15-December-2016

REQUIREMENTS

Standard:	C37.60-2012 Section 6.111.3, "Simulated Surge Arrester Operation Test"
-----------	--

Test Voltage and Current: 120 kV_{peak} (150 kV_{peak} x 0.8), 6 kA_{peak}

Configurations:

Condition	Description of Applied Impulses	Point of Application	Switch Position
A	15 surges of (+) polarity and 15 surges of (-) polarity	source bushings	open
B	15 surges of (+) polarity and 15 surges of (-) polarity	source bushings	closed
C	15 surges of (+) polarity and 15 surges of (-) polarity	load bushings	closed
D	15 surges of (+) polarity and 15 surges of (-) polarity	properly rated transformer	open
E	15 surges of (+) polarity and 15 surges of (-) polarity	properly rated transformer	closed

TEST RESULTS:

The recloser and controls continued to function after all surges had been applied.

CONCLUSION:

The recloser and controls complied with the requirements of IEEE Standard C37.60-2012, Section 6.11.3.

Report Prepared By: Nader Samara, Lab Associate G&W Electric	Date: 29-December-2016
Signed by: <i>Vincent TAPPEL</i>	Date: 1-12-17.

B- Beckwith 42pin design

SPECIMEN DESCRIPTION

Recloser Control:	Beckwith 42pin		
Control Part #	M7679-V6L1ML6ELT2C0000 / M-2979-A32B01DW109SUTY0		
Control Serial #	1091		
Three-phase Recloser:	G&W Viper ST Type VIP388ER-12-1-ST		
Impulse level (BIL):	125 kV _{peak}		
Rated Voltage:	27 kV _{rms}		
Rated Current:	800 A _{rms} continuous		
Viper ST Serial No.:	2016 0824 0049		
Reference drawing: N.A.	Photographs attached:	Yes: <input checked="" type="checkbox"/>	No: <input type="checkbox"/>

Dates of Test: 16-December-2016 through 19-December-2016

REQUIREMENTS

Standard:	C37.60-2012 Section 6.111.3, "Simulated Surge Arrester Operation Test"
-----------	--

Test Voltage and Current: 120 kV_{peak} (150 kV_{peak} x 0.8), 6 kA_{peak}

Configurations:


Condition	Description of Applied Impulses	Point of Application	Switch Position
A	15 surges of (+) polarity and 15 surges of (-) polarity	source bushings	open
B	15 surges of (+) polarity and 15 surges of (-) polarity	source bushings	closed
C	15 surges of (+) polarity and 15 surges of (-) polarity	load bushings	closed
D	15 surges of (+) polarity and 15 surges of (-) polarity	properly rated transformer	open
E	15 surges of (+) polarity and 15 surges of (-) polarity	properly rated transformer	closed

TEST RESULTS:


The recloser and controls continued to function after all surges had been applied.

CONCLUSION:


The recloser and controls complied with the requirements of IEEE Standard C37.60-2012, Section 6.11.3.




SSAO setup for recloser with 32pin design




SSAO test setup for recloser with 42pin design



SSAO test setup for the transformer



Beckwith control 32pin design



Beckwith control 42pin design



Beckwith display screen