CERTIFICATE OF COMPLIANCE

Certificate Number E84940

Report Reference E84940-20191004

Date 2022-April-26

Issued to: HAWKE INTERNATIONAL, DIV OF HUBBELL LTD

OXFORD ST W

ASHTON-UNDER-LYNE 0L7 ONA GB

This is to certify that MARINE : representative samples of ZONE CL

MARINE SHIPBOARD CABLE FITTINGS FOR USE IN ZONE CLASSIFIED HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page for Standard(s) for Safety


Additional Information: See the UL Online Certifications Directory at

https://ig.ulprospector.com for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.





CERTIFICATE OF COMPLIANCE

Certificate Number E84940

Report Reference E84940-20191004

Date 2022-April-26

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Marine Shipboard Cable Sealing Fitting, Type 753, may be followed by M, followed by letters Os, O, A, B, C, C2, D, E or F. For use in Class I, Division 1, Groups A, B, C and D; Class II, Groups E, F and G; Class III Hazardous Locations. For use with the manufacturer's sealing compounds Hawkeseal 2 (EP2132), Hawkeseal 3 (QSP2122), or Express (X099-41-2). For use only with marine shipboard cable employing copper, bronze, aluminum or steel grounding braid. Thread size 1/2 to 3 in. NPT inclusive or M16 to M75 inclusive, for vertical or horizontal mounting. These fittings are intended for installation on mobile offshore oil rigs and drilling platforms in accordance with United States Coast Guard Electrical Engineering Regulations 46CFR110, 46CFR111, 46CFR112 and 46CFR113, as applied by the Authority Having Jurisdiction.

Marine Shipboard Cable Sealing Fitting, Type 753, may be followed by M, followed by letters Os, O, A, B, C, C2, D, E or F. For use in Class I, Zone 1, AEx d IIC; Class I, Zone 1, AEx e IIC; Zone 21, AEx tb IIIC. For use with the manufacturer's sealing compounds Hawkeseal 2 (EP2132), Hawkeseal 3 (QSP2122), or Express (X099-41-2). For use only with marine shipboard cable employing copper, bronze, aluminum or steel grounding braid and sealing compound. Thread size 1/2 to 3 in. NPT inclusive or M16 to M75 inclusive, for vertical or horizontal mounting. These fittings are intended for installation on mobile offshore oil rigs and drilling platforms in accordance with Sub-part 111.60 of the United States Coast Guard Electrical Engineering Regulations, Subchapter J (Title 46 of Federal Regulation, Parts 110 to 113 incl.) as applied by the Authority Having Jurisdiction.

Marine Shipboard Cable Sealing Fitting, Type 753, may be followed by M, followed by letters Os, O, A, B, C, C2, D, E or F. For use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III Hazardous Locations. For use with the manufacturer's sealing compounds Hawkeseal 2 (EP2132), Hawkeseal 3 (QSP2122), or Express (X099-41-2). For use only with marine shipboard cable employing copper, bronze, aluminum or steel grounding braid. Thread size 1/2 to 3 in. NPT inclusive or M16 to M75 inclusive, for vertical or horizontal mounting. These fittings are intended for installation on mobile offshore oil rigs and drilling platforms in accordance with the Ships Electrical Standards, TP 127 E, Section 26, as applied by the Authority Having Jurisdiction.

Marine Shipboard Cable Sealing Fitting, Type 753, may be followed by M, followed by letters Os, O, A, B, C, C2, D, E or F. For use in Ex db IIC Gb; Ex eb IIC Gb; Ex tb IIIC Db. For use only with marine shipboard cable employing copper, bronze, aluminum or steel grounding braid. For use with the manufacturer's sealing compounds Hawkeseal 2 (EP2132), Hawkeseal 3 (QSP2122), or Express (X099-41-2). Thread size 1/2 to 3 in. NPT inclusive or M16 to M75 inclusive, for vertical or horizontal mounting.

Bambles

(UL)

Bruce Mahrenholz, Director North American Certification Program

CERTIFICATE OF COMPLIANCE

Certificate Number E84940

Report Reference E84940-20191004

Date 2022-April-26

Standard(s) for Safety:

UL 2225, Cables and Cable-Fittings for Use in Hazardous (Classified) Locations


UL 514B, Conduit, Tubing, and Cable Fittings


UL 50E, Enclosures for Electrical Equipment, Environmental conditions

CSA C22.2 No. 174-18 + Update 1: 02/2022, Cables and cable glands for use in hazardous locations

CSA C22.2 No. 18.3-12, Conduit, Tubing, and Cable Fittings

CSA C22.2 No. 94.2-15 Enclosures for Electrical Equipment, Environmental conditions





UL LLC

