



## RROR.E12145 Receptacles with Plugs for Use in Hazardous Locations

[Page Bottom](#)

### Receptacles with Plugs for Use in Hazardous Locations

[See General Information for Receptacles with Plugs for Use in Hazardous Locations](#)

#### HUBBELL INC (DELAWARE) - VANTAGE DIVISION

E12145

4140 World Houston Pky, Ste 130  
Houston, TX 77032 USA

**Class I, Group B.** 30 amp, 480 v, 60/400 Hz, ac, receptacle Cat. No. GB followed by -B1716 or -O1716, followed by -51SK, -51SL or -51SV, with or without suffix No. 01-06 incl. or 07, followed by -AE, -AF, -BE, -BF, -FE or -FF, with plug Cat. No. GB followed by -1016 or -D1016, followed by -51PK, -51PL or -51PV, with or without suffix No. 01-06 incl. or 07, followed by -06, -08, -10, -12, -14, -16, -18, -20, -22, -23 or -2800 ; receptacle Cat. No. GB followed by -B1716 or -O1716, followed by -23SK, -23SL or -23SV, with or without suffix No. 01-04 incl. or 05, followed by -AE, -AF, -BE, -BF, -FE or -FF, with plug Cat. No. GB followed by -1016 or -D1016, followed by -23PK, -23PL or -23PV, with or without suffix No. 01-04 incl. or 05, followed by -06, -08, -10, -12, -14, -16, -18, -20, -22, -23 or 2800 ; receptacle Cat. No. GB followed by -B1720 or -O1720 followed by -36SK, -36SL or -36SV, with or without suffix No. 01 or 02, followed by -AF, -AJ, -BF, -BJ, -FF or -FJ, with plug Cat. No. GB followed by -1020 or -D1020 followed by -36PK, -36PL or -36PV, with or without suffix No. 01 or 02, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 .

30 amp, 480 v, 60/400 Hz, ac, Reverse service receptacle Cat. No. GB followed by -B1716 or -O1716, followed by -51PK, -51PL or -51PV, with or without suffix No. 01-06 incl. or 07, followed by -AE, -AF, -BE, -BF, -FE or -FF, with plug Cat. No. GB followed by -1016 or -D1016, followed by -51SK, -51SL or -51SV, with or without suffix No. 01-06 incl. or 07, followed by -06, -08, -10, -12, -14, -16, -18, -20, -22, -23 or -2800 ; receptacle Cat. No. GB followed by -B1716 or -O1716, followed by -23PK, -23PL or -23PV, with or without suffix No. 01-04 incl. or 05, followed by -AE, -AF, -BE, -BF, -FE or -FF, with plug Cat. No. GB followed by -1016 or -D1016, followed by -23SK, -23SL or -23SV, with or without suffix No. 01-04 incl. or 05, followed by -06, -08, -10, -12, -14, -16, -18, -20, -22, -23 or 2800 ; receptacle Cat. No. GB followed by -B1720 or -O1720 followed by -36PK, -36PL or -36PV, with or without suffix No. 01 or 02, followed by -AF, -AJ, -BF, -BJ, -FF or -FJ, with plug Cat. No. GB followed by -1020 or -D1020 followed by -36SK, -36SL or -36SV, with or without suffix No. 01 or 02, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 .

60 amp, 480 v, 60/400 Hz, ac, receptacle Cat. No. GB followed by -B1720 or -O1720, followed by -61SK, -61SL or -61SV, with or without suffix No. 01-06 incl. or 07, followed by -AF, -AJ, -BF, -BJ, -FF or -FJ, with plug Cat. No. GB followed by -1020 or -D1020, followed by -61PK, -61PL or -61PV, with or without suffix No. 01-06 incl. or 07, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 ; receptacle Cat. No. GB followed by -B1720 or -O1720, followed by -40SK, -40SL or -40SV, with or without suffix No. 01, 02, 03, or 04, followed by -AF, -AJ, -BF, -BJ, -FF or -FJ, with plug Cat. No. GB followed by -1020 or -D1020, followed by -40PK, -40PL or -40PV, with or without suffix No. 01, 02, 03, or 04, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 ; receptacle Cat. No. GB followed by -B1724 or -O1724, followed by -29SK, -29SL or -29SV, with or without suffix No. 01, 02 or 03, followed by -BJ, with plug Cat. No. GB followed by -1024 or -D1024, followed by -29PK, -29PL or -29PV, with or without suffix No. 01, 02, or 03, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 .

60 amp, 480 v, 60/400 Hz, ac, Reverse service receptacle Cat. No. GB followed by -B1720 or -O1720, followed by -61PK, -61PL or -61PV, with or without suffix No. 01-06 incl. or 07, followed by -AF, -AJ, -BF, -BJ, -FF or -FJ, with plug Cat. No. GB followed by -1020 or -D1020, followed by -61SK, -61SL or -61SV, with or without suffix No. 01-06 incl. or 07, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 ; receptacle Cat. No. GB followed by -B1720 or -O1720, followed by -40PK, -40PL or -40PV, with or without suffix No. 01, 02, 03 or 04, followed by -AF, -AJ, -BF, -BJ, -FF or -FJ, with plug Cat. No. GB followed by -1020 or -D1020, followed by -40SK, -40SL or -40SV, with or without suffix No. 01, 02, 03 or 04, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 ; receptacle Cat. No. GB followed by -B1724 or -O1724, followed by -29PK, -29PL or -29PV, with or without suffix No. 01, 02 or 03, followed by -BJ, with plug Cat. No. GB followed by -1024 or -D1024, followed by -29SK, -29SL or -29SV, with or without suffix No. 01, 02 or 03, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 .

100 amp, 480 v, 60/400 Hz, ac, receptacle Cat. No. GB followed by -B1724 or -O1724, followed by -60SK, -60SL or -60SV, with or without suffix No. 01-06 incl. or 07, followed by -BJ ,

with plug Cat. No. GB followed by -1024 or -D1024, followed by -60PK, -60PL or -60PV, with or without suffix No. 01-06 incl. or 07, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 ; receptacle Cat. No. GB followed by -B1724 or -O1724, followed by -39SK, -39SL or -39SV, with or without suffix No. 01-04 incl. or 05, followed by -BJ with plug Cat. No. GB followed by -1024 or -D1024, followed by -39PK, -39PL or -39PV, with or without suffix No. 01-04 incl. or 05, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 ; receptacle Cat. No. GB followed by -B1728 or -O1728, followed by -23SK, -23SL or -23SV, with or without suffix No. 01, 02 or 03 followed by -BJ, with plug Cat. No. GB followed by -1208 or -D1028, followed by -23PK, -23PL or -23PV, with or without suffix No. 01, 02 or 03, followed by -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 .

100 amp, 480 v, 60/400 Hz, ac, Reverse service receptacle Cat. No. GB followed by -B1724 or -O1724, followed by -60PK, -60PL or -60PV, with or without suffix No. 01-06 incl. or 07, followed by -BJ, with plug Cat. No. GB followed by -1024 or -D1024, followed by -60SK, -60SL or -60SV, with or without suffix No. 01-06 incl. or 07, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 ;

receptacle Cat. No. GB followed by -B1724 or -O1724, followed by -39PK, -39PL or -39PV, with or without suffix No. 01-04 incl. or 05, followed by -BJ with plug Cat. No. GB followed by -1024 or -D1024, followed by -39SK, -39SL or -39SV, with or without suffix No. 01-04 incl. or 05, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 ; receptacle Cat. No. GB followed by -B1728 or -O1728,

followed by -23PK, -23PL or -23PV, with or without suffix No. 01, 02 or 03 followed by -BJ, with plug Cat. No. GB followed by -1028 or -D1028, followed by -23SK, -23SL or -23SV, with or without suffix No. 01, 02 or 03, followed by -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 .

**Class I, Division 2, Group B.** 30 amp, 480 v, 60/400 Hz, receptacle Part No. GB followed by -B1716-23SL, -B1716-51SL, -B1720-36SL for use with plug Part No. GB followed by -1016-23PL, -1016-51PL, -1020-36PL, respectively. 60 amp, 480 v, 60/400 Hz, receptacle Part No. GB followed by -B1720-40SL, -B1720-61SL, -B1724-29SL for use with plug Part No. GB followed by -1020-40PL, -1020-61PL, -1024-29PL, respectively. 100 amp, 480 v, 60/400 Hz receptacle GB followed by -B1724-39SL, -B1724-60SL, -B1728-23SL for use with plug Part No. GB followed by -1024-39PL, -1024-60PL, -1028-23PL , respectively.

**Class I, Groups C and D.** 30 amp, 480 v, 60/400 Hz, ac, receptacle Cat. No. GD followed by -B1716, -F1716 or -O1716, followed by -51SK, -51SL or -51SV, with or without suffix No. 01-06 incl. or 07, followed by -AE, -AF, -AG, -AH, -BE, -BF, -BG, -BH, -FE, -FF, -FG or -FH, with plug Cat. No. GD followed by -1016 or -D1016, followed by -51PK, -51PL or -51PV, with or without suffix No. 01-06 incl. or 07, followed by -06, -08, -10, -12, -14, -16, -18, -20, -22, -23 or -2800 ; receptacle Cat. No. GD followed by -B1716, -F1716 or -O1716, followed by -23SK, -23SL or -23SV, with or without suffix No. 01-04 incl. or 05, followed by -AE, -AF, -AG, -AH, -BE, -BF, -BG, -BH, -FE, -FF, -FG or -FH, with plug Cat. No. GD followed by -1016 or -D1016, followed by -23PK, -23PL or -23PV, with or without suffix No. 01-04 incl. or 05, followed by -06, -08, -10, -12, -14, -16, -18, -20, -22, -23 or -2800 ; receptacle Cat. No. GD followed by -B1720, -F1720 or -O1720, followed by -36SK, -36SL or -36SV, with or without suffix No. 01 or 02, followed by -AF, -AG, -AH, -AJ, -BF, -BG, -BH, -BJ, -FF, -FG, -FH or -FJ, with plug Cat. No. GD followed by -1020 or -D1020, followed by -36PK, -36PL or -36PV, with or without suffix No. 01 or 02, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 .

30 amp, 480 v, 60/400 Hz, ac, Reverse service receptacle Cat. No. GD followed by -B1716, -F1716 or -O1716, followed by -51PK, -51PL or -51PV, with or without suffix No. 01-06 incl. or 07, followed by -AE, -AF, -AG, -AH, -BE, -BF, -BG, -BH, -FE, -FF, -FG or -FH ,

with plug Cat. No. GD followed by -1016 or -D1016, followed by -51SK, -51SL or -51SV, with or without suffix No. 01-06 incl. or 07, followed by -06, -08, -10, -12, -14, -16, -18, -20, -22, -23 or -2800 ; receptacle Cat. No. GD followed by -B1716, -F1716 or -O1716, followed by -23PK, -23PL or -23PV, with or without suffix No. 01-04 incl. or 05, followed by -AE, -AF, -AG, -AH, -BE, -BF, -BG, -BH, -FE, -FF, -FG or -FH, with plug Cat. No. GD followed by -1016 or -D1016, followed by -23SK, -23SL or -23SV, with or without suffix No. 01-04 incl. or 05, followed by -06, -08, -10, -12, -14, -16, -18, -20, -22, -23 or -2800 ; receptacle Cat. No. GD followed by -B1720, -F1720 or -O1720, followed by -36PK, -36PL or -36PV, with or without suffix No. 01 or 02, followed by -AF, -AG, -AH, -AJ, -BF, -BG, -BH, -BJ, -FF, -FG, -FH or -FJ, with plug Cat. No. GD followed by -1020 or -D1020, followed by -36SK, -36SL or -36SV, with or without suffix No. 01 or 02, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 .

60 amp, 480 v, 60/400 Hz, ac, receptacle Cat. No. GD followed by -B1720, -F1720 or -O1720, followed by -61SL, -61SK or -61SV, with or without suffix No. 01-06 incl. or 07, followed by -AF, -AG, -AH, -AJ, -BF, -BG, -BH, -BJ, -FF, -FG, -FH or -FJ, with plug Cat. No. GD followed by -1020 or -D1020, followed by -61PK, -61PL or -61PV, with or without suffix No. 01-06 incl. or 07, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 ;

receptacle Cat. No. GD followed by -B1720, -F1720 or -O1720, followed by -40SK, -40SL or -40SV, with or without suffix No. 01, 02, 03 or 04, followed by -AF, -AG, -AH, -AJ, -BF, -BG, -BH, -BJ, -FF, -FG, -FH or -FJ, with plug Cat. No. GD followed by -1020 or -D1020, followed by -40PK, -40PL or -40PV, with or without suffix No. 01, 02, 03 or 04, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 ; receptacle Cat. No. GD followed by -B1724, -F1724 or -O1724, followed by -29SK, -29SL or -29SV, with or without suffix No. 01, 02 or 03, followed by -BH, -BJ or -BK, with plug Cat. No. GD followed by -1024 or -D1024, followed by -29PK, -29PL or -29PV, with or without suffix No. 01, 02 or 03, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 .

60 amp, 480 v, 60/400 Hz, ac, Reverse service receptacle Cat. No. GD followed by -B1720, -F1720 or -O1720, followed by -61PK, -61PL or -61PV, with or without suffix No. 01-06 incl. or 07, followed by -AF, -AG, -AH, -AJ, -BF, -BG, -BH, -BJ, -FF, -FG, -FH or -FJ, with plug Cat. No. GD followed by -1020 or -D1020, followed by -61SK, -61SL or -61SV, with or without suffix No. 01-06 incl. or 07, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 ;

receptacle Cat. No. GD followed by -B1720, -F1720 or -O1720, followed by -40PK, -40PL or -40PV, with or without suffix No. 01, 02, 03 or 04, followed by -AF, -AG, -AH, -AJ, -BF, -BG, -BH, -BJ, -FF, -FG, -FH or -FJ, with plug Cat. No. GD followed by -1020 or -D1020, followed by -40SK, -40SL or -40SV, with or without suffix No. 01, 02, 03 or 04, followed by -10, -12, -14, -16, -18, -20, -22, -24, -26, -28, -30, -31 or -2800 ; receptacle Cat. No. GD followed by -B1724, -F1724 or -O1724, followed by -29PK, -29PL or -29PV, with or without suffix No. 01, 02 or 03, followed by -BH, -BJ or -BK, with plug Cat. No. GD followed by -1024 or -D1024, followed by -29SK, -29SL or -29SV, with or without suffix No. 01, 02 or 03, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 .

100 amp, 480 v, 60/400 Hz, ac, receptacle Cat. No. GD followed by -B1724, -F1724 or -O1724, followed by -60SK, -60SL or -60SV, with or without suffix No. 01-06 incl. or 07, followed by -BH, -BJ or -BK, with plug Cat. No. GD followed by -1024 or -D1024, followed by -60PK, -60PL or -60PV, with or without suffix No. 01-06 incl. or 07, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 ; receptacle Cat. No. GD followed by -B1724, -F1724 or -O1724 ,

followed by -39SK, -39SL or -39SV, with or without suffix No. 01-04 incl. or 05, followed by -BH, -BJ or -BK, with plug Cat. No. GD followed by -1024 or -D1024, followed by -39PK, -39PL or -39PV, with or without suffix No. 01-04 incl. or 05, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 ; receptacle Cat. No. GD followed by -B1728, -F1728 or -O1728, followed by -23SK, -23SL or -23SV, with or without suffix No. 01, 02 or 03, followed by -BK or -BL, with plug Cat. No. GD followed by -1028 or -D1028, followed by -23PK, -23PL or -23PV, with or without suffix No. 01, 02 or 03, followed by -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 .

100 amp, 480 v, 60/400 Hz, ac, Reverse service receptacle Cat. No. GD followed by -B1724, -F1724 or -O1724, followed by -60PK, -60PL or -60PV, with or without suffix No. 01-06 incl. or 07, followed by -BH, -BJ or -BK, with plug Cat. No. GD followed by -1024 or -D1024, followed by -60SK, -60SL or -60SV, with or without suffix No. 01-06 incl. or 07, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 ; receptacle Cat. No. GD followed by -B1724, -F1724 or -O1724, followed by -39PK, -39PL or -39PV, with or without suffix No. 01-04 incl. or 05, followed by -BH, -BJ or -BK, with plug Cat. No. GD followed by -1024 or -D1024, followed by -39SK, -39SL or -39SV, with or without suffix No. 01-04 incl. or 05, followed by -16, -18, -20, -22, -24, -26, -28, -30, -32, -34, -36, -38, -39 or -2800 ;

receptacle Cat. No. GD followed by -B1728, -F1728 or -O1728, followed by -23PK, -23PL or -23PV, with or without suffix No. 01, 02 or 03, followed by -BK or -BL, with plug Cat. No. GD followed by -1028 or -D1028, followed by -23SK, -23SL or -23SV, with or without suffix No. 01, 02 or 03, followed by -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 .

200 amp, 480 v, 60/400 Hz, ac, receptacle Cat. No. GDU followed by -B1728 or -O1728, followed by -30SK, -30SL or -30SV, with or without suffix No. 01-09 incl. or 10, followed by -BK or -BL, with plug Cat. No. GDU followed by -1028 or -D1028, followed by -30PK, -30PL or -30PV, with or without suffix No. 01-09 incl. or 10, followed by -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 ; receptacle Cat. No. GDU followed by -B1728 or -O1728, followed by -31SK, -31SL or -31SV, with or without suffix No. 01, 02 or 03, followed by -BK or -BL,

with plug Cat. No. GDU followed by -1028 or -D1028, followed by -31PK, -31PL or -31PV, with or without suffix No. 01, 02 or 03, followed by -20, -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 .

200 amp, 480 v, 60/400 Hz, ac, Reverse service receptacle Cat. No. GDU followed by -B1728 or -O1728, followed by -30PK, -30PL or -30PV, with or without suffix No. 01-09 incl. or 10, followed by -BK or -BL, with plug Cat. No. GDU followed by -1028 or -D1028, followed by -30SK, -30SL or -30SV, with or without suffix No. 01-09 incl. or 10, followed by -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 ;

receptacle Cat. No. GDU followed by -B1728 or -O1728, followed by -31PK, -31PL or -31PV, with or without suffix No. 01, 02 or 03, followed by -BK or -BL, with plug Cat. No. GDU followed by -1028 or -D1028, followed by -31SK, -31SL or -31SV, with or without suffix No. 01, 02 or 03, followed by -20, -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 .

200 amp, 480 v, 60/400 Hz, auxiliary contacts 480 v, ac, standard pilot duty; receptacle Cat. No. GDT followed by -B1728 or -O1728, followed by -42SK, -42SL or -42SV with or without suffix -01, -02 or -03, followed by -BK or -BL, with plug Cat. No. GDT followed by -1028 or -D1028, followed by -42PK, -42PL or -42PV with or without suffix -01, -02 or -03, followed by -20, -24, -26, -28, -30, -32, -34, -36, -38, -40, -42, -44, -46 or -2800 .

Types GD , GDT , GDU receptacles, rain tight when installed in concrete, for use with Types GD , GDT , GDU plugs. Rated 30 , 60 , 100 , 200 amp, 480 v, 60/400 Hz, ac, auxiliary contacts 480 v, ac, standard pilot duty. Receptacle No. GD followed by A1, A2, B1, B2, B3, C1, C2, C3, D1, D3, D4 or D5, followed by K, L or V, with or without suffix numbers, followed by 92 or 93, followed by suffix letters and/or numbers. Plug No. GD or GDU, with or without suffix letter D, followed by 1016, 1020, 1024 or 1028, followed by 23, 29, 30, 31, 36, 39, 40, 51, 60 or 61, followed by P, followed by K, L or V, followed by suffix numbers. Plug No. GDT with or without suffix letter D, followed by 1028, followed by 42, followed by P, followed by K, L or V, followed by suffix numbers. Type ERR receptacles, Type EPD plugs.

Receptacle Cat. No.	Plug Cat. No.	V AC 60-Cy. 1-Phase	HP	Amps
ERRA-11532, -115322	EPD-31532, -41532,	120 or 240	1	20
	or -51532			
ERRA-21532, -215322	EPD-31532, -41532,	120 or 240	1	20
	or -51532			
ERRA-31532, -315322	EPD-31532, -41532,	120 or 240	1	20
	or -51532			
ERRC-11532, -115322	EPD-31532, -41532,	120 or 240	1	20
	or -51532			
ERRC-21532, -215322	EPD-31532, -41532,	120 or 240	1	20
	or -51532			
ERRC-31532, -315322	EPD-31532, -41532,	120 or 240	1	20
	or -51532			
ERRA-23032, -230322	EPD-43032, -53032, -63032,	120 or 240	1-1/2	30
	or -73032	480	1/2	7
ERRA-33032, -330322	EPD-43032, -53032, -63032,	120 or 240	1-1/2	30
	or -73032	480	1/2	7
ERRC-23032, -230322	EPD-43032, -53032, -63032,	120 or 240	1-1/2	30
	or -73032	480	1/2	7
ERRC-33032, -330322	EPD-43032, -53032, -63032,	120 or 240	1-1/2	30
	or -73032	480	1/2	7
ERRA-11542, -115422	EPD-31542, -41542, or -51542	120 or 240	1-1/2	20
ERRA-21542, -215422	EPD-31542, -41542, or -51542	120 or 240	1-1/2	20
ERRA-31542, -315422	EPD-31542, -41542, or -51542	120 or 240	1-1/2	20
ERRC-11542, -115422	EPD-31542, -41542, or -51542	120 or 240	1-1/2	20
ERRC-21542, -215422	EPD-31542, -41542, or -51542	120 or 240	1-1/2	20
ERRC-31542, -315422	EPD-31542, -41542, or -51542	120 or 240	1-1/2	20
ERRA-23042, -230422	EPD-43042, -53042, -63042, or	120 or 240	3	1
	-73042	480	1	7

ERRA-33042, -330422	EPD-43042, -53042, -63042, or	120 or 240	3	30
	-73042	480	1	7
ERRC-23042, -230422	EPD-43042, -53042, -63042, or	120 or 240	3	30
	-73042	480	1	7
ERRC-33042, -330422	EPD-43042, -53042, -63042, or	120 or 240	3	30
	-73042	480	1	7

**Class I, Division 2, Groups C and D.** 30 amp, 480 v, 60/400 Hz, receptacle Part No. GD followed by -B1716-23SL, -B1716-51SL, -B1720-36SL for use with plug Part No. GD followed by -1016-23PL, -1016-51PL, -1020-36PL, respectively. 60 amp, 400 v, 60/400 Hz, receptacle Part No. GD followed by -B1720-40SL, -B1720-61SL, -B1724-29SL for use with plug Part No. GD followed by -1020-40PL, -1020-61PL, -1024-29PL, respectively. 100 amp, 480 v, 60/400 Hz, receptacle Part No. GD followed by -B1724-39SL, -B1724-60SL, -B1728-23SL for use with plug Part No. GD followed by -1024-39PL, -1024-60PL, -1028-23PL, respectively. 200 amp, 480 v, 60/400 Hz, receptacles Part Nos. GDT-B1728-42SL, GDU-B1728-30SL, GDU-B1728-31SL for use with plugs GDT-1028-42PL, GDU-1028-30PL, and GDU-1028-31PL, respectively.

Last Updated on 2017-02-13

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".