

SIDE VIEW SURFACE MOUNT

GENERAL NOTES: (READ SHEETS COMPLETELY BEFORE STARTING)

1. LEAVE PROTECTIVE WRAPPING MATERIAL ON FIXTURES UNTIL START OF INSTALLATION TO PROTECT FINISH FROM DAMAGE.

2. FIXTURES ARE SUPPLIED WITH FACTORY INSTALLED BRANCH CIRCUIT WIRING. REFER TO SUPPLEMENTAL INSTRUCTION SHEET WHEN MAKING CONNECTIONS.

3. APPROXIMATE WEIGHT OF FIXTURE IS 3.50 LBS PER FOOT OF LENGTH.

	TOOLS REQUIRED	SUPPLIED BY INSTALLER
	SCREWDRIVER OR 1/4" HEX DRIVER/SOCKET	ANCHOR MOUNTING SCREWS FENDER WASHERS
	7/16" HEX DRIVER/SOCKET OR WRENCH	



DO NOT MODIFY OR ALTHER THIS PRODUCT IN ANY WAY, OR INSTALL IN ANY FASHION WHICH IS CONTRARY TO THE INSTRUCTIONS CONTAINED HEREIN. IF YOU HAVE ANY QUESTIONS REGARDING THIS PRODUCT OR THE INSTALLATION OF IT, PLEASE CALL LITECONTROL ENGINEERING AT 781-294-0100

DRAWING: 510674

REV / DATE: 1 / 10/27/2021

INSTALLATION INSTRUCTIONS

FIXTURE SERIES: 2L

2

MOUNTING TYPE: SURFACE

SOME COMPONENTS HIDDEN FOR CLAIRITY

BRING POWER
FEED INTO 7/8" KO


TETHER

FIXTURE

REMOVE THE END CAP ASSEMBLIES BY PULLING END CAP TO DISENGAGE MAGNETS. FOR INDIVIDUAL FIXTURE, DO SO AT BOTH ENDS. FOR ROW, DO SO AT NEAR END OF 1ST FIXTURE AND FAR END OF LAST FIXTURE.

FIXTURE—Sometime of the contract of the contrac

TO REMOVE LENS, PULL LENS DOWN TO DISENGAGE LENS FROM FIXTURE. FOR INDIVIDUAL FIXTURE, REMOVE ONE END CAP PER STEP 1.



PAGE: 2 OF 3

REMOVE REFLECTOR ASSEMBLY AND LET REFLECTOR ASSEMBLY HANG ON TETHERS.

MOUNTING SCREWS

CEILING

FIXTURES

LIFT FIXTURE UP NEAR CEILING . BRING ELECTRICAL FEED THRU 7/8" HOLE AND INTO FIXTURE WIREWAY.

RAISE 1ST FIXTURE FLUSH TO CEILING. SECURE WITH (2) ANCHOR SCREWS AND WASHERS. (SUPPLIED BY INSTALLER) THROUGH MOUNTING SLOTS INTO CEILING STRUCTURE.

SOME COMPONENTS HIDDEN FOR CLAIRITY

EXTRUSION BRACKET,
MALE FIXTURE.


FLANGE NUTS

CARRIAGE BOLT

EXTRUSION BRACKET,
FEMALE FIXTURE.

MAKE WIRING CONNECTIONS
IN EITHER LOCATION

REPEAT STEPS 1-4 FOR ALL INTERMEDIATE FIXTURES. RAISE INT (OR END OF ROW FEMALE) FIXTURES UP AND SLIDE ONTO PROTRUDING BRACKET. INSTALL 5/16-18 X 4.5" CARRIAGE BOLT TO SECURE FIXTURES TOGETHER. ATTACH 5/16-18 FLANGE NUT ON OTHER SIDE OF JOINT AS SHOWN. ALIGN SEAMS BEFORE FULLY TIGHTENING NUT. TIGHTEN ANCHOR SCREWS FROM STEP 4.



MAKE ELECTRICAL CONNECTIONS IN FIXTURE WIREWAY. IF INSTALLING ROW OF FIXTURES, ELECTRICAL FEED CAN BE AT ANY 7/8" HOLE LOCATION. BRANCH CIRCUIT WIRES CAN BE BROUGHT THROUGH EACH ROW JOINT.



DO NOT MODIFY OR ALTHER THIS PRODUCT IN ANY WAY, OR INSTALL IN ANY FASHION WHICH IS CONTRARY TO THE INSTRUCTIONS CONTAINED HEREIN. IF YOU HAVE ANY QUESTIONS REGARDING THIS PRODUCT OR THE INSTALLATION OF IT, PLEASE CALL LITECONTROL ENGINEERING AT 781-294-0100


DRAWING: 510674

REV / DATE: 1 / 10/27/2021


LENS REMOVAL

8

END CAP MTG PLATE REMOVAL



FIXTURE





TO REMOVE, PULL LENS DOWN TO DISENGAGE LENS FROM FIXTURE FOR INDIVIDUAL FIXTURE, REMOVE ONE END CAP PER STEP 1.

TO REMOVE END CAP MOUNTING PLATE REMOVE THE 6-32 MACHINE SCREWS SHOWN ABOVE.

9

LED REFLECTOR ASSEMBLY REMOVAL





∠REFLECTOR ASSEMBLY

BEFORE REMOVING LED REFLECTOR ASSEMBLY SEE STEP 7 FOR LENS REMOVAL. TO REMOVE LED REFLECTOR ASSEMBLY:


REMOVE THE (2) #8 SHEET METALS SCREWS AS SHOWN.

DISCONNECT WIRE NUTS THAT CONNECT LED WIRES TO DRIVER.

DISCONNECT SAFETY TETHERS CONNECTED TO THE LED REFLECTOR ASSEMBLY.

10

DRIVER REMOVAL



BEFORE REMOVING DRIVER SEE STEPS 7 AND 9 FOR LENS AND LED REFL REMOVAL. REMOVE THE (2) SCREWS AS SHOWN AND REMOVE DRIVER.



DO NOT MODIFY OR ALTHER THIS PRODUCT IN ANY WAY, OR INSTALL IN ANY FASHION WHICH IS CONTRARY TO THE INSTRUCTIONS CONTAINED HEREIN. IF YOU HAVE ANY QUESTIONS REGARDING THIS PRODUCT OR THE INSTALLATION OF IT, PLEASE CALL LITECONTROL ENGINEERING AT 781-294-0100

DRAWING: 510674

REV / DATE: 1 / 10/28/2021