
Cable Gland Assembly Instructions APEX E1FX





TECHNICAL DATA

Cable Gland Type: Apex E1FX

Equipment Type: Group II Compression Cable Gland

Ingress Protection: IP66, IP67 **Operating Temp:** -60°C to +130°C

INSTALLATION NOTES

- All cable glands must be installed by a suitably trained and competent individual.
- Cable gland entry threads are machined in accordance with BS 3643 6g (Metric) or ANSI/ASME B1.20.1 (NPT)
- The enclosure material shall be compatible with the cable gland. The material used shall not introduce environmental factors that affect the type of protection
- To maintain IP ratings, Hawke recommends the use of a Hawke IP washer or other approved sealing method.
- To ensure effective sealing of an IP washer, enclosure sealing face surface finish shall be smooth and free from damage. The entry hole should be drilled perpendicular to the sealing face.
- When using enclosures with plain through holes, Hawke recommends nominal +0.3mm of diametric clearance over the major diameter of the thread. For example, to accommodate an M20 entry, drill 20.3 diameter.
- Enclosure wall thickness is dependent on gland entry thread length, style of enclosure entry hole (threaded or plain), protection concept of the installation and the required use of accessories. The installer should be aware of and specify for these requirements, for example Exd requires 5 full threads of metric engagement in line with 60079-14.
- External earth tags are recommended to be fitted adjacent to the flange of the cable gland entry, so they remain in direct contact with the cable gland. Any sealing washer should be placed between tag and enclosure. For more information on placement of accessories, visit www.hubbell.com/hawke.

CERTIFICATION DETAILS

Ex db eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da

ATEX: CML23ATEX1003X CML19ATEX4507X (Ex nR) UKEX: CML23UKEX1005X CML21UKEX4133X (Ex nR) IECEx: IECEx CML23.0002X IECEx CML21.0012 (Ex nR)

ACCESSORIES

Hawke offer the following accessories to enable correct sealing and ground of cable gland.

Shroud: For additional corrosion protection Locknut: To secure gland into position Sealing Washer: For additional ingress protection Earth Tag: For external bonding point Serrated Washer: To prevent vibration loosening locknuts

SPECIFIC CONDITIONS OF USE

The following conditions relate to safe installation and/or use of the equipment.

- When the glands are used for increased safety, dust protection and/or restricted breathing, the entry thread shall be suitably sealed (in accordance with EN / IEC 60079-14) to maintain the ingress protection rating of the associated enclosure. Not applicable when Hawke IP 66/67 sealing washer is used.
- The glands have a service temperature of -60°C to +130°C.
- Glands for use with unarmoured or braided cables are only suitable for fixed installations, the cable for which must be effectively clamped to prevent pulling and twisting (does not apply when fitted with rear clamping device or Hawke Gland Mounted Clamp (GMC).

The torque values below are a general recommendation and may vary dependent on cable type. For best result, tighten in line with the number of turns described in the instructions STEPS 6 & 7.

Torque Figures Nm										
Gland Size	Os	0	А	В	С	C2	D	Е	F	
Middlenut Torque	5-10	5-10	8-15	10-20	15-25	25-40	25-40	40-45	55-75	
Backnut Torque	8-12	8-12	8-12	8-12	15-20	25-30	30-35	40-45	40-45	

EU Declaration of Conformity and UK Attestation of Conformity in accordance with European Directive 2014/34/EU and UK Statutory Instrument 2016/1107

Manufacturer: Hawke International, Oxford Street West, Ashton-under-Lyne, OL7 0NA, United Kingdom Equipment: APEX E1FX Cable Gland
Provisions of the Directive fulfilled by the Equipment: Group II Category 2G Ex db eb IIC Gb, 3G Ex nR IIC Gc, 1D Ex ta IIIC Da – IP66/67

Harmonized Standards used: EN 60079-0:2018, EN60079-1:2014, EN60079-7:2015+A1:2018, EN60079-15:2019, EN60079-31:2014

Notified Body for EU-Type Examination: CML B.V. 2776 Amsterdam, NLD EU-type Examination Certificate: CML23ATEX1003X, CML19ATEX4507X (Ex nR) Notified Body for production: 0598

Approved Body for UK-Type Examination: CML B.V. 2503 Chester, UK UK-type Examination Certificate: CML23UKEX1005X, CML21UKEX4133X (Ex nR) Approved Body for production: 1180

On behalf of the above named company, I declare that on the date the equipment, accompanied by this declaration, is placed on the market the equipment conforms with all technical and regulatory requirements of the above listed directives.







CABLE GLAND SELECTION TABLE													
	Entro	road Ciao	Cable Acceptance Details								d Max	Hexagon Dimensions	
Entry Thread Size		Inner Sheath			Outer Sheath		Armour						
Size Retric Metric		Standard Seal Alternation		ve Seal (S)		Sileatii	Clamp Ring		gth				
	Metric	ric NPT	Min.	Max.	Min.	Max.	Min.	Max.	Equipment Side	Equipment Side	Approx Installed Max Length	Across Flats	Across Corners
Os	M16/M20	1/2"	2.5	7.5			7.2	16.0	0 - 0.8		64.0	24.0	26.5
0	M16/M20	1/2"	6.5	11.3			7.2	16.0	0 - 0.8		64.0	24.0	26.5
Α	M20	1/2" - 3/4"	10.0	14.3	9.0	13.4	12.5	20.8	0 - 0.8		65.5	30.0	32.5
В	M25	3⁄4" - 1"	13.0	19.5	9.5	15.4	18.0	27.0	0 - 0.7	0.5 - 1.0	76.0	36.0	39.5
С	M32	1" - 1¼"	19.5	26.4	15.5	21.2	24.5	33.0	0 - 0.7	0.5 - 1.25	78.0	46.0	50.5
C2	M40	11⁄4″ - 11⁄2″	25.0	32.4	22	28	31.0	41.5	0 - 0.7	0.5 - 1.25	89.0	55.0	60.6
D	D M50	1½"	21.5	42.3*			36.0	51.7	0 - 0.7	0.5 - 1.6	1040	65.0	70.8
D M50	2″	31.5	43.3			36.0	51.7	0 - 0.7	0.5 - 1.0	104.0	65.0	70.8	
E M63	2″	42.5	54.3*	38.0	46.5	53.0	64.5	0 - 0.7	0.5 - 1.6	104.0	80.0	88.0	
	2½″		55.0								80.0	88.0	
F	M75	2½″	EAE	65.3*	53.0	58.3	64.0	77.5	0 - 0.7	0.5 - 1.6	106.0	05.0	104.0
F W173	3″	54.5	66.7	53.0	36.3	04.0	77.5	0-0.7	0.5 - 1.6	106.0	95.0	104.0	

All dimensions in millimetres (except NPT where dimensions are in inches)

B: Cable Preparation

Separate factory assembled cable gland into Entry Assembly (A) and Backnut/Middlenut Assembly (B) while setting the Armour Clamp Ring (5) & Spigot (4) to the side.

Optionally, install the Entry (1) into enclosure using the appropriate IP sealing method as defined by the application.


Slide shroud (if included), Backnut/Middlenut Assembly (B) onto the cable.


Cut cable to desired length and strip outer sheath.

Measure the braid/armour diameter/thickness, select orientation of Clamp Ring (5) and install on the Cable. Then cut braid to lengths as

*If cable has an inner tape; strip that back to the same length as the braid.

**If the braids overlap each other; select correct orientation based on 2x measured diameter.





Strip Length							
D:	Gland Size						
Dim	Os-C	C2-F					
Х	20mm	25mm					
у	To suit equipment						

Images for illustration purposes only Product supplied may differ from that shown Al2059- Issue D / Page 2 of 4

Os - F size metric entry threads are 1.5mm pitch as standard, 15mm length of thread *Smaller diameters apply when selecting smaller diameter NPT entry threadform.


C: Installing Cable Gland

Step 1: Fit Braid to Spigot

Slide Spigot (4) over cable.


Push braid up to Spigot (4) shoulder.

Slide Armour Clamp Ring (5) up to the braid by hand.



Step 2: Prepare to Clamp Armour

Ensure Inner Seal (3) is removed from assembly.




Note: A spare entry component could be used to clamp the armourings, which removes the need to remove the inner seal of the gland to be assembled.

Step 3: Clamp Armour

Slide Middlenut (6) up to Entry (1) and hand tighten.

Support the cable to prevent it twisting. Grip the Entry (1) with a spanner/wrench. Use a second spanner/wrench to tighten the Middlenut (6) half to three quarters of a turn.




Step 4: Inspect Braid

Unscrew the Middlenut (6). The Armour Clamp Ring (5) should now be locked in place.

Inspect that the braid has been successfully clamped between the Spigot (4) and the Armour Clamp Ring (5).

If clamping is not satisfactory, repeat Step 3, with an additional 1/4 turn and repeat the inspection.




Images for illustration purposes only. Product supplied may differ from that shown.

Diameter Scale (mm) Correct when printed A4 Booklet Style

Al2059 - Issue D / Page 3 of 4


Step 5: Install Inner Seal

Remove Backnut/Middlenut Assembly (B) and refit Inner Seal (3). Install Entry (1) to enclosure. If required, use the appropriate IP washer.



Step 6: Compress Inner Seal

With Inner Seal (3) properly seated into the Entry (1), re-introduce the cable, tighten up the Middlenut (6) until the resistance of the spigot against the inner seal is felt. Use a spanner/wrench to tighten a further number of turns per table.




APEX INNER SEAL TIGHTENING GUIDE											
NUMBER OF TURNS TO	GLAND SIZE										
	Os	0	А	В	С	C2	D	E	F		
TIGHTEN	CABLE DIAMETER RANGE (mm)										
7								42.5 - 44	54.5 - 56		
6		6.5 - 7		13 - 14			31.5 - 34	44 - 47	56 - 58.5		
5	2.5 - 3.3	7 - 8.2		14 - 15.6			34 - 36.5	47 - 50	58.5 - 61		
4	3.3 - 4.7	8.2 - 9.3	10 - 11.2	15.6 - 16.8	19.5 - 21.5	25 - 27.5	36.5 - 39	50 - 52.5	61 - 63		
3	4.7 - 6.2	9.3 - 10.3	11.2 - 12.5	16.8 - 18.2	21.5 - 23.5	27.5 - 30.5	39 - 42	52.5 - 55	63 - 65.5		
2	6.2 - 7.5	10.3 - 11.2	12.5 - 13.8	18.2 - 19.3	23.5 - 26.4	30.5 - 32.4	42 - 44		65.5 - 67.5		
1		11.2 - 11.8	13.8 - 14.4	19.3 - 19.7							

Step 7: Install Backnut

Tighten the Backnut (9) until a seal is visually seen around the cable.

Use a spanner/wrench to grip the Middlenut (6).

While preventing the Middlenut (6) turning, use a second spanner/wrench to apply one further full turn to the Backnut (9).



Step 8: Completion

Installation now complete.

Fit Shroud if Applicable.

