


# Cable Gland Assembly Instructions

## APEX E1FW

### A: Component Parts



#### TECHNICAL DATA

|                            |                                  |
|----------------------------|----------------------------------|
| <b>Cable Gland Type:</b>   | Apex E1FW                        |
| <b>Equipment Type:</b>     | Group II Compression Cable Gland |
| <b>Ingress Protection:</b> | IP66, IP67                       |
| <b>Operating Temp:</b>     | -60°C to +130°C                  |

#### INSTALLATION NOTES

- All cable glands must be installed by a suitably trained and competent individual.
- Cable gland entry threads are machined in accordance with BS 3643 6g (Metric) or ANSI/ASME B1.20.1 (NPT).
- The enclosure material shall be compatible with the cable gland. The material used shall not introduce environmental factors that affect the type of protection applied.
- To maintain IP ratings, Hawke recommends the use of a Hawke IP washer or other approved sealing method.
- To ensure effective sealing of an IP washer, enclosure sealing face surface finish shall be smooth and free from damage. The entry hole should be drilled perpendicular to the sealing face.
- When using enclosures with plain through holes, Hawke recommends nominal +0.3mm of diametric clearance over the major diameter of the thread. For example, to accommodate an M20 entry, drill 20.3 diameter.
- Enclosure wall thickness is dependent on gland entry thread length, style of enclosure entry hole (threaded or plain), protection concept of the installation and the required use of accessories. The installer should be aware of and specify for these requirements, for example Exd requires 5 full threads of metric engagement in line with 60079-14.
- External earth tags are recommended to be fitted adjacent to the flange of the cable gland entry, so they remain in direct contact with the cable gland. Any sealing washer should be placed between tag and enclosure. For more information on placement of accessories, visit [www.hubbell.com/hawke](http://www.hubbell.com/hawke).

#### CERTIFICATION DETAILS

|  |                          |
|--|--------------------------|
| Ex db eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da |                          |
| ATEX: CML23ATEX1003X                           | CML19ATEX4507X (Ex nR)   |
| UKEX: CML23UKEX1005X                           | CML21UKEX4133X (Ex nR)   |
| IECEX: IECEX CML23.0002X                       | IECEX CML21.0012 (Ex nR) |

#### ACCESSORIES

Hawke offer the following accessories to enable correct sealing and ground of cable gland.

|                         |   |
|-------------------------|---|
| <b>Shroud:</b>          | For additional corrosion protection     |
| <b>Locknut:</b>         | To secure gland into position           |
| <b>Sealing Washer:</b>  | For additional ingress protection       |
| <b>Earth Tag:</b>       | For external bonding point              |
| <b>Serrated Washer:</b> | To prevent vibration loosening locknuts |

#### SPECIFIC CONDITIONS OF USE

The following conditions relate to safe installation and/or use of the equipment.

- When the glands are used for increased safety, dust protection and/or restricted breathing, the entry thread shall be suitably sealed (in accordance with EN / IEC 60079-14) to maintain the ingress protection rating of the associated enclosure. Not applicable when Hawke IP 66/67 sealing washer is used.
- The glands have a service temperature of -60°C to +130°C.
- Glands for use with unarmoured or braided cables are only suitable for fixed installations, the cable for which must be effectively clamped to prevent pulling and twisting (does not apply when fitted with rear clamping device or Hawke Gland Mounted Clamp (GMC)).

#### TORQUE VALUES

The torque values below are a general recommendation and may vary dependent on cable type. For best result, tighten in line with the number of turns described in the instructions STEPS 6 & 7.

| Torque Figures Nm |      |      |      |       |       |       |       |       |       |
|-------------------|------|------|------|-------|-------|-------|-------|-------|-------|
| Gland Size        | Os   | O    | A    | B     | C     | C2    | D     | E     | F     |
| Middenut Torque   | 5-10 | 5-10 | 8-15 | 10-20 | 15-25 | 25-40 | 25-40 | 40-45 | 55-75 |
| Backnut Torque    | 8-12 | 8-12 | 8-12 | 8-12  | 15-20 | 25-30 | 30-35 | 40-45 | 40-45 |

#### EU Declaration of Conformity and UK Attestation of Conformity in accordance with European Directive 2014/34/EU and UK Statutory Instrument 2016/1107

**Manufacturer:** Hawke International, Oxford Street West, Ashton-under-Lyne, OL7 0NA, United Kingdom

**Equipment:** APEX E1FW Cable Gland

**Provisions of the Directive fulfilled by the Equipment:** Group II Category 2G Ex db eb IIC Gb, 3G Ex nR IIC Gc, 1D Ex ta IIIC Da – IP66/67

**Harmonized Standards used:** EN 60079-0:2018, EN60079-1:2014, EN60079-7:2015+A1:2018, EN60079-15:2019, EN60079-31:2014

**Notified Body for EU-Type Examination:** CML B.V. 2776 Amsterdam, NLD

**EU-type Examination Certificate:** CML23ATEX1003X, CML19ATEX4507X (Ex nR)

**Notified Body for production:** 0598


**Approved Body for UK-Type Examination:** CML B.V. 2503 Chester, UK

**UK-type Examination Certificate:** CML23UKEX1005X, CML21UKEX4133X (Ex nR)

**Approved Body for production:** 1180

On behalf of the above named company, I declare that on the date the equipment, accompanied by this declaration, is placed on the market the equipment conforms with all technical and regulatory requirements of the above listed directives.

  
Andrew Reid  
Technical Manager

| CABLE GLAND SELECTION TABLE  |                   |           |                          |       |            |      |              |      |                |  |                             |                    |                |      |
|--|-------------------|-----------|--------------------------|-------|------------|------|--------------|------|----------------|--|-----------------------------|--------------------|----------------|------|
| Size Ref.  | Entry Thread Size |           | Cable Acceptance Details |       |            |      |              |      |                |  | Approx Installed Max Length | Hexagon Dimensions |                |      |
|  |                   |           | Inner Sheath             |       |            |      | Outer Sheath |      | Armour         |  |                             |                    |                |      |
|  | Standard Seal     |           | Alternative Seal (S)     |       | Clamp Ring |      |              |      |                |  |                             |                    |                |      |
|  | Metric            | NPT       | Min.                     | Max.  | Min.       | Max. | Min.         | Max. | Equipment Side | Equipment Side   |                             | Across Flats       | Across Corners |      |
| Os   | M16/M20           | ½"        | 2.5                      | 7.5   |            |      | 7.2          | 16.0 | 0.8 -1.25      |  |                             | 64.0               | 24.0           | 26.5 |
| O  | M16/M20           | ½"        | 6.5                      | 11.3  |            |      | 7.2          | 16.0 | 0.8 -1.25      |  |                             | 64.0               | 24.0           | 26.5 |
| A  | M20               | ½" - ¾"   | 10.0                     | 14.3  |            |      | 9.0          | 13.4 | 12.5           |  |                             | 20.8               | 0.8 -1.25      | 65.5 |
| B  | M25               | ¾" - 1"   | 13.0                     | 19.5  | 9.5        | 15.4 | 18.0         | 27.0 | 0.8 -1.25      | 1.25 - 1.6   | 76.0                        | 36.0               | 39.5           |      |
| C  | M32               | 1" - 1¼"  | 19.5                     | 26.4  | 15.5       | 21.2 | 24.5         | 33.0 | 1.25 - 1.6     | 1.6 - 2.0  | 78.0                        | 46.0               | 50.5           |      |
| C2   | M40               | 1¼" - 1½" | 25.0                     | 32.4  | 22         | 28   | 31.0         | 41.5 | 1.25 - 1.6     | 1.6 - 2.0  | 89.0                        | 55.0               | 60.6           |      |
| D  | M50               | 1½"       | 31.5                     | 42.3* |            |      | 36.0         | 51.7 | 1.6 - 2.0      | 2.0 - 2.5  | 104.0                       | 65.0               | 70.8           |      |
|  |                   | 2"        |                          | 43.3  |            |      |              |      |                |  |                             |                    |                |      |
| E  | M63               | 2"        | 42.5                     | 54.3* | 38.0       | 46.5 | 53.0         | 64.5 | 1.6 - 2.0      | 2.0 - 2.5  | 104.0                       | 80.0               | 88.0           |      |
|  |                   | 2½"       |                          | 55.0  |            |      |              |      |                |  |                             |                    |                |      |
| F  | M75               | 2½"       | 54.5                     | 65.3* | 53.0       | 58.3 | 64.0         | 77.5 | 1.6 - 2.0      | 2.0 - 2.5  | 106.0                       | 95.0               | 104.0          |      |
|  |                   | 3"        |                          | 66.7  |            |      |              |      |                |  |                             |                    |                |      |
| All dimensions in millimetres (except NPT where dimensions are in inches)<br>Os - F size metric entry threads are 1.5mm pitch as standard, 15mm length of thread<br>*Smaller diameters apply when selecting smaller diameter NPT entry threadform. |                   |           |                          |       |            |      |              |      |                |  |                             |                    |                |      |

B: Cable Preparation


Separate factory assembled cable gland into Entry Assembly (A) and Backnut/Middlenut Assembly (B) while setting the Armour Clamp Ring (5) & Spigot (4) to the side.

Optionally, install the Entry (1) into enclosure using the appropriate IP sealing method as defined by the application.

Slide shroud (if included), Backnut/Middlenut Assembly (B) onto the cable.

Cut cable to desired length and strip outer sheath.

Measure the braid/armour diameter/thickness, select orientation of Clamp Ring (5) and install on the Cable. Then cut armour to lengths as shown.



| Strip Length |                   |      |
|--------------|-------------------|------|
| Dim          | Gland Size        |      |
|              | Os-C              | C2-F |
| x            | 20mm              | 25mm |
| y            | To suit equipment |      |




## C: Installing Cable Gland

### Step 1 : Fit Armour to Spigot

Slide Spigot (4) over cable.

Push armour up to Spigot (4) shoulder.


Slide Armour Clamp Ring (5) up to the armour by hand.



### Step 2 : Prepare to Clamp Armour

Ensure Inner Seal (3) is removed from assembly.

Slide Entry (1) over cable.




**Note:** A spare entry component could be used to clamp the armourings, which removes the need to remove the inner seal of the gland to be assembled.

### Step 3 : Clamp Armour

Slide Middlednut (6) up to Entry (1) and hand tighten.

Support the cable to prevent it twisting. Grip the Entry (1) with a spanner/wrench. Use a second spanner/wrench to tighten the Middlednut (6) half to three quarters of a turn.




### Step 4 : Inspect Armour

Unscrew the Middlednut (6). The Armour Clamp Ring (5) should now be locked in place.


Inspect that the armour has been successfully clamped between the Spigot (4) and the Armour Clamp Ring (5).

If clamping is not satisfactory, repeat Step 3, with an additional 1/4 turn and repeat the inspection.




Step 5 : Install Inner Seal

Remove Backnut/Middlenut Assembly (B) and refit Inner Seal (3). Install Entry (1) to enclosure. If required, use the appropriate IP washer.



Step 6 : Compress Inner Seal


With Inner Seal (3) properly seated into the Entry (1), re-introduce the cable, tighten up the Middlenut (6) until the resistance of the spigot against the inner seal is felt. Use a spanner/wrench to tighten a further number of turns per table.



| APEX INNER SEAL TIGHTENING GUIDE |                           |             |             |             |             |             |           |           |             |
|----------------------------------|---------------------------|-------------|-------------|-------------|-------------|-------------|-----------|-----------|-------------|
| NUMBER OF TURNS TO TIGHTEN       | GLAND SIZE                |             |             |             |             |             |           |           |             |
|                                  | O <sub>s</sub>            | O           | A           | B           | C           | C2          | D         | E         | F           |
|                                  | CABLE DIAMETER RANGE (mm) |             |             |             |             |             |           |           |             |
| 7                                |                           |             |             |             |             |             |           | 42.5 - 44 | 54.5 - 56   |
| 6                                |                           | 6.5 - 7     |             | 13 - 14     |             |             | 31.5 - 34 | 44 - 47   | 56 - 58.5   |
| 5                                | 2.5 - 3.3                 | 7 - 8.2     |             | 14 - 15.6   |             |             | 34 - 36.5 | 47 - 50   | 58.5 - 61   |
| 4                                | 3.3 - 4.7                 | 8.2 - 9.3   | 10 - 11.2   | 15.6 - 16.8 | 19.5 - 21.5 | 25 - 27.5   | 36.5 - 39 | 50 - 52.5 | 61 - 63     |
| 3                                | 4.7 - 6.2                 | 9.3 - 10.3  | 11.2 - 12.5 | 16.8 - 18.2 | 21.5 - 23.5 | 27.5 - 30.5 | 39 - 42   | 52.5 - 55 | 63 - 65.5   |
| 2                                | 6.2 - 7.5                 | 10.3 - 11.2 | 12.5 - 13.8 | 18.2 - 19.3 | 23.5 - 26.4 | 30.5 - 32.4 | 42 - 44   |           | 65.5 - 67.5 |
| 1                                |                           | 11.2 - 11.8 | 13.8 - 14.4 | 19.3 - 19.7 |             |             |           |           |             |

Step 7 : Install Backnut

Tighten the Backnut (9) until a seal is visually seen around the cable. Use a spanner/wrench to grip the Middlenut (6). While preventing the Middlenut (6) turning, use a second spanner/wrench to apply one further full turn to the Backnut (9).



Step 8 : Completion

Installation now complete. Fit Shroud if Applicable.

