

C MPASS

Outdoor Wet Location LED Emergency Light

IMPORTANT SAFEGUARDS


When using electrical equipment, basic safety precautions should always be followed including the following.

READ AND FOLLOW ALL SAFETY INSTRUCTIONS

- Rated for temperature range of 10°C-40°C (50°F-104°F) and suitable for use in an application that is designated as a wet location area as defined by NEC Article 100, Location, wet.
- 2. Used indoors or outdoors.
- Equipment should be mounted in locations and at heights (Max: 9ft) where it will not be subject to tampering by unauthorized personnel.
- 4. Do not mount near gas or electric heaters.
- 5. The use of accessory equipment is not recommended by the manufacturer and may cause an unsafe condition.
- 6. Do not use this equipment for anything other than its intended use.
- 7. Servicing of this equipment should be performed by qualified personnel.
- 8. Disconnect AC power before servicing.

INSTALLER:

•SEE UNIT LABEL FOR ADDITIONAL MODEL SPECIFICATIONS
•SAVE THESE INSTRUCTIONS FOR USE BY OWNER/OCCUPANT





tradeSELECT[®]

INSTALLATION

J-Box Mounting

- 1. Open the Base plate and lead out a wire after getting through the hole on the Base plate. Fix the Base plate on J-Box with screws.
- 2. Then connect to AC power (Fig.4).
- 3. Connect to the battery with connectors (Fig.5/ Fig.6).
- 4. Install the housing to Base plate, turn on the AC power and press the "TEST" button check light (Fig.8).

Conduit

- 1. Use tool such as flat head screw driver to open the housing. (Fig.1)
- 2. Hold the unit by one hand and use tool to pry the 2 lock buttons at the base plate (Fig.2), separate the unit from the base plate (Fig.3).
- 3. Secure Base Plate to wall surface. Route wires through hole in conduit flange and make conduit connection. Use flexible conduit only.
- 4. Connect battery before continuous AC power is being supplied to the unit (Fig. 5/ Fig. 6).
- 5. Press the unit back onto the base plate, make sure it be hold by the lock buttons. (Fig. 7)
- 6. Align snaps and push housing directly onto the Base Plate (Fig. 8). Apply continuous AC power and press "TEST" button to check light.



Fig. 1




Fig. 2



Fig. 3





Warning: Unused wires must be capped using enclosed wire nuts

Operation

- 1. During an electrical power failure, the lamps on the unit will automatically come ON for a minimum of 90 minutes.
- 2. 2. To test this unit, let it charge correctly with AC power supply for a minimum of 24 hours after its first installation and then depress the "TEST" switch, the emergency lamps will illuminate. When the switch is released, the lamps will turn OFF.

