


INSTALLATION, OPERATION AND MAINTENANCE INSTRUCTIONS

HDL106T - Transportable Floodlight *ATEX & IECEx*


Important:

Please read these instructions carefully before installing or maintaining this equipment. Good electrical practices should be followed at all times and this data should be used as a guide only.













Type Of Protection	Ex e mb (Increased safety,encapsulation), Ex tb (dust)			
Protection Standards	(IEC) EN 60079-0, (IEC) EN 60079-7, (IEC) EN 60079-18, (IEC) EN 60079-31			
Area Classification	Zone 1 and Zone 2 areas to (IEC) EN 60079-10-			
	Zone 21 and Zone 22 areas to (IEC) EN 60079-10-2			
Installation	(IEC) EN 60079-14			
Certificate	IECEx Certificate of Conformity IECEx SIR 10.0055X			
	EU - Type Examination Certificate Sira 10ATEX5115X			
Equipment Coding	HDL106TN	HDL106TN		
-	100V to 254V 50/60Hz	18V to 54V AC/DC		
*ambient ratings vary	Ex e mb IIC T4 Gb	Ex e mb IIC T4 Gb		
depending on the	Ex tb IIIC T103°C Db IP6X	Ex tb IIIC T87°C Db IP6X		
plug/sockets connected to	-20°≤ Ta ≤+50°C	-20°≤ Ta ≤+55°C		
the luminaire.	or			
	Ex e mb IIC T3 Gb			
	Ex tb IIIC T103°C Db IP6X			
	-20°≤ Ta ≤+59.5°C			
ATEX Coding				
Ingress Protection	IP66/67			
Laser safety class	Class 1 LED product			
CE Mark	The CE marking of this product applies to "The Electrical Equipment (Safety) Regulations			
	2006", "The Electromagnetic Compatibility Reg			
	Electronic Equipment Regulations 2006" and	' '		
(←	intended for use in Explosive Atmospheres Regulations 1996". [This legislation is the			
	equivalent in UK law of EU directives 2014/35/EU, 2014/30/EU, 2012/19/EU and 2014/34/EU			
	respectively].			
	The Environment is designed to mark the magnitions of the ATEV direction			
	The Equipment is declared to meet the provisions of the ATEX directive			
	(2014/34/EU) by reason of the EU Type Examination and compliance with the Essential Health and Safety Requirements.			
	M Poutney Technical Manager			
	INTO GUICY TECHNICAL MANAGE			



SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number).

- 1. When the Lexan polycarbonate lens is fitted, the HDL106T Modular Floodlight/Bulkhead shall not be moved while connected to an electrical supply. When in use, the equipment shall be supported and mounted in a fixed and stable arrangement. The equipment shall be removed from the hazardous area if dropped and shall be inspected in order to determine its continued suitability for use in the hazardous
- 2. Except for internal wiring, not more than one single or multiple strand lead shall be connected into either side of any terminal, unless multiple conductors have been joined in a suitable manner, e.g. two conductors into a single insulated crimped boot lace ferrule.
- 3. Leads connected to the terminals shall be insulated for the appropriate voltage and this insulation shall extend to within 1 mm of the metal of the terminal throat.
- 4. When terminals in accordance with certificate Sira 01ATEX3247U are used, all terminal screws, used and unused, shall be tightened down to between 0.5 Nm and 0.7 Nm.
- 5. When terminals in accordance with certificate Sira 01ATEX3249U are used, all terminal screws, used and unused, shall be tightened down to between 1.2 Nm and 2 Nm.
- 6. When terminals in accordance with certificates Sira 01ATEX3247U and Sira 01ATEX3249U are used, they shall only be installed and wired with cable within a temperature range of -10°C to 80°C.
- 7. When cross-connecting combs are used on terminals to certificates Sira 01ATEX3247U and Sira 01ATEX3249U, the relevant conditions associated with those certificates shall be applied.
- 8. Cable entry holes shall be fitted with either an appropriately certified cable gland or appropriately certified blanking element. These shall provide and maintain a minimum enclosure ingress protection of IP66 or IP67 as appropriate.
- 9. If more than 8 individual LEDs are not illuminated, the LED assembly shall be replaced.
- 10. The supply circuit must be protected by a fuse capable of withstanding a prospective short circuit current of 1500 A.
- 11. The HDL106E and HDL106NE, the battery powered emergency versions, are suitable for an ambient temperature range of -20°C to +50°C when installed with the terminal cross-link in accordance with the manufacturer's installation instructions, which achieves a 100% output, i.e. 48 illuminated LEDs. The HDL106E and HDL106NE are suitable for an ambient temperature range of -20°C to +55°C when the terminal cross-link is not installed, which achieves 50% output, i.e. 24 illuminated LEDs.
- 12. When the Lexan polycarbonate lens is fitted, the equipment shall only be used in areas with a low risk of mechanical impact.
- 13. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.

1.0 Introduction

The Chalmit HDL106 Transportable range brings to hazardous areas the very latest in lighting technology. It is a compact light source that uses ultra bright light emitting diodes to provide light from mains power. The LEDs are maintenance free and can last up to 150,000 + hours @ 25°C ambient (L70). They are housed in an impact and corrosion resistant marine grade aluminium enclosure with a toughened glass or polycarbonate lens. The control gear is electronic with regulated lamp output. The LEDs work equally well at very low temperatures as they do at high and produce a product with very low overall power consumption.

Important:

Electrostatic Charging Hazard: Clean only with a damp cloth, when fitted with a polycarbonate lens.



LED White High Power.

Voltage ranges: 100 - 254V 50/60 Hz

18 - 54V AC/DC

Electrical Operating	24 x LED HDL106TN	48 x LED HDL106TN	
Power Watts	27W	53W	
Current Amps	0.29 - 0.11A	0.56 - 0.22A	

Electrical Operating	24 x LED HDL106TN	48 x LED HDL106TN	
Power Watts	27W	53W	
Current Amps	1.5 – 0.49A	2.9 - 0.98A	

For lumen output photometric data can be requested.

Power Factor 0.9 minimum

Over voltage 375V

Linkable Ambient restrictions apply when linking multiple units with CEAG Sockets. Please

contact Chalmit Technical for further information.

Luminaires are to be stored in cool dry conditions -20°C to +50°C Storage

preventing ingress of moisture and condensation.

PAT Testing (Insulation) 500V DC MAX for 1 min

1.0 **Installation and Safety**

1.1 General

There are no health hazards associated with this product whilst in normal use. However, care should be exercised during the following operations. Installation should be carried out in accordance with EN/IEC 60079-14 or the local hazardous area code of practice, whichever is appropriate, and fitting of specified insulating material to be adhered to where a specific fire resistance rating is required. In the UK the requirements of the 'Health and Safety at Work Act' must be met.

Handling and electrical work associated with this product to be in accordance with the 'Manual Handling Operations Regulations' and 'Electricity at Work Regulations, 1989'. Your attention is drawn to the paragraphs (i) 'Electrical Supplies', (ii) 'Electrical Fault Finding and Replacement' and (iii) 'Inspection and Maintenance'. The luminaires are class 1 and should be effectively earthed. Certification details on the rating plate must be verified against the application requirements before installation.

The user must ensure that there is no potential difference between the earth supply to the luminaire and the local earth. If this is not possible, the external earth on the product should be used to earth the luminaire to metalwork in the surrounding environment.

The information in this leaflet is correct at the time of publication. The company reserves the right to make specification changes as required.

1.2 Use in Combustible Dust Atmospheres

Where the equipment is used in ignitable dust atmospheres reference must be made to the selection and installation standards in order that the equipment is used correctly. In particular this applies to the de-rating of surface temperature for use where dust clouds may be present. Dust layers should not be allowed to accumulate on the surface and good housekeeping is required for safe operation. Dust in layers has the potential to form ignitable clouds and to burn at lower temperatures.

Refer to EN (IEC) 60079-10-2 & EN (IEC) 60079-14 for additional details of selection and installation.

1.3 Hybrid Mixtures – Gas and Dust

I-HDL106-09.doc 01/01/2021 Issue 3



Where hybrid mixtures exist as defined in EN 1127 as a potentially explosive atmosphere, consideration should be given to verifying that the maximum surface temperature of the luminaire is below the ignition temperature of the hybrid mixture.

1.4 Tools

5mm Allen Key (Hex)

Spanners for installing cable glands. Pliers, knife, wire strippers/cutters.

2.0 Electrical Supplies

A maximum voltage variation of +6%/-6% on the nominal is expected. (The safety limit for T rating is +10%). Equipment must not be operated outside of the rated voltage of the control gear. The lamp supply is regulated therefore the light output over the supply range is constant.

3.0 LED Array & Driver

This product is fitted with LEDs that can last up to 150,000 + hours @ 25°C ambient (L70). Therefore in many applications replacement of the LED array will be unnecessary. If replacement is required ensure mains supplies are isolated before commencing work. Remove the front cover and then remove the LED array assembly. Care must be taken when disconnecting and reconnecting wiring. If required contact Chalmit Technical.

4.0 Inspection and maintenance

Visual inspection should be carried out before each use to ensure that the housing and cable show no signs of damage; refer to EN/IEC 60079-17. For details of spare cable, plug and socket assemblies, please contact Chalmit.

5.0 Electrical fault finding and replacement

Any fault finding must be done by a competent electrician with the luminaire isolated and, if carried out with the luminaire in place, under a permit to work. Fault finding is by substitution with known good components.

6.0 Routine Maintenance

Visual tests and checks should be carried out at intervals described by the appropriate regulations, EN/IEC 60079-17, and should include the following:

Check that the LEDs are working.

Check for mechanical damage/corrosion.

Check for loose connections including earthing.

Check for undue accumulations of dust or dirt.

Verification of tightness of fixing, glands, blanking plugs etc. *Torque Values- Stirrup mounting point: 10Nm, Aluminium/Glass Diffuser fixing screws: 4Nm, Polycarbonate Diffuser fixing screws: 1.5 - 2Nm.*

Check for unauthorised modifications.

Check condition of enclosure gasket and fastenings.

Check for any accumulation of moisture.

Periodic inspection of the enclosure seal should be carried out to ensure that the seal is sound.

If the luminaire has been subject to abnormal conditions, for example, severe mechanical impact or chemical spillage, it must be de-energised until it has been inspected by an authorised and competent person. If in doubt, the unit should be returned to Chalmit for examination and, if necessary, replacement.

Before re-assembling, all connections should be checked and any damaged cable replaced.

7.0 Disposal of Material

The unit is mainly made from incombustible materials. The control gear contains plastic resin and electronic components. All electrical components may give off noxious fumes if incinerated. Take care to render these fumes harmless or avoid inhalation. Any local regulations concerning disposal must be complied with. Any disposal must satisfy the requirements of the <u>WEEE directive [2012/19/EU]</u> and therefore must not be treated as commercial waste.





To comply with the Waste Electrical and Electronic Equipment directive 2012/19/EU the apparatus cannot be classified as commercial waste and as such must be disposed of or recycled in such a manner as to reduce the environmental impact.

Chalmit Lighting is a leading supplier of Hazardous Area lighting products



CHALMIT LIGHTING

PO Box 5575 Glasgow, G52 9AP Scotland



Telephone: +44 (0) 141 882 5555
Fax: +44 (0) 141 883 3704
Email: info@chalmit.com
Web: www.chalmit.com

Registered No: 669157 Registered Office: Cannon


Cannon Place 78 Cannon Street London EC4N 6AF UK

For technical support, please contact: techsupport@chalmit.com

 $Note: Chalmit\ Lighting\ reserves\ the\ right\ to\ amend\ characteristics\ of\ our\ products\ and\ all\ data\ is\ for\ guidance\ only.$




HIGH VOLTAGE





LOW VOLTAGE



Note: For 24 LED luminaires, there will only be one LED array connected to the terminal block.



. ☆ ☆ ☆.	EU-Declaration	of conformity				
		E-Déclaration de conformité				
	EU-Konformitä	U-Konformitätserklärung				
Manufacturer	Chalmit	Address	388 Hillingto	n Road. C	Glasgow. G52 4BL Sco	otland UK
Product		rtable Modular Floodlight/Bu		,	g	
	nination Certificate	Sira 10ATEX5115X				
Notified Body		CSA Group Netherlands B.V. 2813				
ATEX Coding		⟨ ξ χ⟩ Ⅱ 2 GD				
g		(EX) 112 GD			g	
Equipment Cod	ling:					
HDL106TN		Ex e mb IIC T4 Gb , Ex tb IIIC T103°C Db IP6X -20° C \Box Ta \Box +50 $^{\circ}$ C				
100V to 254V 5	0/60Hz	or ExembIICT3Gb,	or Ex e mb IIC T3 Gb , Ex tb IIIC T103°C Db IP6X -20° C \Box Ta \Box +59.5 $^{\circ}$ C			
HDL106TN (18	V to 54V AC/DC)	Ex e mb IIC T4 Gb , Ex	x tb IIIC T87°C	Db IP6X	-20°C □ Ta □ +55	<u>°C</u>
Ingress Protect		IP66/67				
The technical b	asis, with respect to	equivalence of				
La base technic	que, en ce qui conce	rne l'équivalence de				
Die technische	Grundlage hinsichtlic	ch der Normen				
Protection Stan	dards EN 60079-0, E	EN 60079-7, EN 60079-18,	EN 60079-31	l		
Area Classificat	tion EN 60079-10-1a	ind EN 60079-10-2				
						gical progress of the product.
	avec les EESS est v	alide puisqu'il n'y a aucun	changement	qui affec	te matériellement l'éta	t de l'évolution technologique du
produit.						
zur Erfüllung de	er GSGA ist gegeben	n, da keine Anderungen erfo	olgt sind, die e	einen Einf	luss auf den technisch	en Stand des Produkts haben.
				1		1
Terms of the di					d & Date Certified to	Standards Date Declared to
Prescription de					d & date certifiée à	Normes date Déclaré
Bestimmungen	der Richtlinie:				d & Datum	Standards Datum erklärt
2014/34/EU	I			Zertifizie		
2014/04/20	Equipment and protective systems intended for use in		tor use in		79-0: 2012	2018
2014/34/UE	potentially explosi				79-7: 2007	2015
2014/34/0L	• •	ystèmes de protection des			79-18: 2009	2015
		hères potentiellement explo zsysteme zur bestimmungs		EN 600	79-31: 2009	EN 60079-31: 2014
201.70.720		dung in explosionsfähigen E				
	1.5					
2014/30/EU	Electromagnetic c	ompatibility		EN 550	15 : 2013	
2014/30/UE		Compatibilité électromagnétique			EN 61547 : 2009	
2014/30/EU			EN 61000-3-2 : 2014			
	3	<u> </u>				
2014/35/EU	Low voltage equipment			EN 6059	98-1 : 2015	
2014/35/UE		ments électriques à bas voltage			98-2-5 : 2015	
2014/35/EU	Niederspannungs				29 : 1992	
	,	,		1.25		
2012/19/EU	Waste of electrical	I and electronic equipment				
2012/19/UE		nents électriques et électroi	niques			
2012/19/EU		ektrischen und elektronisch				
	Systeme	=				
	ľ					
2011/65/EU	RoHS II Directive					



On behalf of the Chalmit, I declare that, on the date the equipment accompanied by this declaration is placed on the market, the equipment conforms to all technical and regulatory requirements of the above listed directives.

En tant que représentant du fabricant Chalmit, je déclare qu'à la date où les équipements accompagnant cette déclaration sont mis sur le marché, ceux-ci sont conformes à toutes les dispositions réglementaires et techniques des directives énumérées ci-dessus.

Hiermit bestätige ich, im Namen von Chalmit, dass am Tag der Lieferung des Produkts/der Produkte zusammen mit dieser Erklärung das Gerät/die Geräte alle technischen und regulativen Anforderungen der oben aufgeführten Direktiven erfüllt.

Name und Datum

Quality Assurance Notification by:

Name and Date

Nom et Date

Notification d'assurance qualité par: Qualitätssicherungsnotifikation durch:

Mark Poutney 01/01/2021

0598

SGS Fimko OY

Technical Manager Directeur technique Technischer Leiter

> Système de Management Qualité Accréditation: Qualitätsmanagementsystem Akkreditierung: Environmental Management System. Système de gestion de l'environnement. Umwelt kontroll system.

Quality Management System Acreditation:

Certificate No./Certificat N°/Zertifikat Nr.

ISO 9001

MIR

150 9001

ISO 14001 by/par/durch Loyd's Register LRQ 4005876